



This programme is co-funded
by the European Union
and the Government of Montenegro



REPORT FROM THE FINITE ELEMENT MODELING AND EXPERIMENTAL INVESTIGATION

**Project: Design and development of prototypes of aluminum
poles for the power system CFCU/MNE/272**

INPUT PARAMETERS FOR DESIGN OF ALUMINUM TRUSS POLES FOR LOW-VOLTAGE LINES

The goal of the proposed project is to create a prototype of aluminum alloy poles for the transmission and distribution of electricity.

The key challenges arise from the need to optimize the poles in accordance with the configuration of the terrain and climatic conditions, as well as their parameters at the micro and macro level. The planned prototype of pillars made of aluminum alloys corresponds to the goals of sustainable development and energy efficiency in Montenegro. The project also fits into the strategies of sustainable development and green energy at the level of Montenegro and the European Union, supporting innovation, resource conservation and environmental protection.

Preliminary research in the field of aluminum application for transmission line pole constructions with a focus on design optimization, efficiency, profitability and structural integrity, the following conclusions were made:

- Advantages of high-strength aluminum alloys: Preference is given to the use of high-strength aluminum alloys compared to other aluminum alloys, with special emphasis on the use of alloys from the 6000 series;
- Optimization of aluminum profiles: Research on the use of aluminum sections obtained by applying the extrusion process as a substitute for traditional sections that are characteristic of steel structures of existing transmission lines, focusing on structural integrity, economy and optimization of the weight of said structures;
- Experimental tests of aluminum profiles: Conducting experimental studies of the behavior of extruded aluminum profiles under pressure, with the aim of contributing to the development of new design rules and optimization of the use of aluminum in constructions;
- Structural modeling and analysis: Focusing on the calculation and analysis of transmission line poles under wind load, emphasizing the consideration of dynamic load for more precise design and ensuring a higher degree of safety;
- Case Studies on Aluminum Transmission Poles: Examining case studies where aluminum has been used to construct transmission lines, demonstrating its economic advantages and reliability compared to steel.


The project task defined the production of an aluminum column with a height of 12 m, which must be loaded with a resultant concentrated force of 10 kN at the top of the support in the elastic zone. The experimental test is performed for the last segment of the lattice girder.

FINITE ELEMENT MODEL

Modeling of the poles was carried out in the Tower 7 software package from Radimpex. Truss members are modeled as linear elements that can be axially loaded in compression or tension. The actual geometric characteristics of the cross-sections are defined. Material characteristics for the corresponding aluminum alloys as well as for the heat-affected zone are also incorporated in the model. Due to the software limited capabilities, as it is made for design of steel structures, there had to be made two models for each design solution:









1. Model with the material characteristic of HAZ to check the load-bearing capacity of members in vicinity to the weld;
2. Model with material characteristics of the base material to check the stability of elements due to high slenderness and possibility of buckling.

Load was applied as static in the nodes at top of the truss in two nodes as concentrated forces perpendicular to the pole. The truss is supported with the simple supports with prevented displacement in any orthogonal direction but with free rotations around all axes.




CONCEPTUAL DESIGN

As a result of finite element modeling, the following eight FEM models fulfilled the project task.


			
ST1 6061 T6	ST1 6082 T6	ST2 6061 T6	ST2 6082 T6
			
ST3 6061 T6	ST3 6082 T6	ST4 6061 T6	ST5 6082 T6


As all design solutions have the same performance, the most optimal solution was selected based on the amount of material required and the hours of manual labor spent on the prototype. Therefore, design solution with the code name ST5 6082 T6 emerged as the most optimal one based on previously mentioned criteria. Design solution ST5 6082 T6 is a truss with a triangular base of an equilateral triangle. It is designed using the alloy EN AW-6082-T6, which represents the alloy with the highest load capacity in the 6000 series of aluminum alloys.

RESULTS FROM FEM




Isometry






Ram: K_1



Ram: K_2




Ram: H_1

Table of materials

No	Material name	E[kN/m ²]	ν	γ [kN/m ³]	ν t1[C]	E _m [kN/m ²]	ν m
1	Aluminum	7.000e+7	0.30	27.00	2.300e-5	7.000e+7	0.30


Beam sets

Set: 1 Section: D= 88.9x6, Prost stick, Fictitious eccentricity




Matte.	A1	A2	A3	I1	I2	I3
1 - Aluminum	1.1663e-3	7.809e-4	7.809e-4	1.2697e-6	1.349e-6	1.349e-6

Set: 2 Section: D= 76.1x5, Prost stick, Fictitious eccentricity




Matte.	A1	A2	A3	I1	I2	I3
1 - Aluminum	1.117e-3	5.581e-4	5.581e-4	1.1418e-6	1.27092e-7	7.092e-7

Set: 3 Section: D= 60.3x4, Simple rod, Fictitious eccentricity




Matte.	A1	A2	A3	I1	I2	I3
1 - Aluminum	7.070e-4	3.536e-4	3.536e-4	1.5632e-7	2.817e-7	2.817e-7

Set: 4 Section: D= 33.7x3, Prost stick, Fictitious eccentricity




Matte.	A1	A2	A3	I1	I2	I3
1 - Aluminum	2.890e-4	1.446e-4	1.446e-4	1.6879e-8	3.440e-8	3.440e-8

Set: 5 Section: D= 26.9x2.5, Simple rod, Fictitious eccentricity




Matte.	A1	A2	A3	I1	I2	I3
1 - Aluminum	1.920e-4	9.577e-5	9.577e-5	1.2881e-8	1.440e-8	1.440e-8

Set: 6 Section: D= 26.9x2.5, Simple rod, Fictitious eccentricity




Matte.	A1	A2	A3	I1	I2	I3
1 - Aluminum	1.920e-4	9.577e-5	9.577e-5	1.2881e-8	1.440e-8	1.440e-8

Set: 7 Section: D=26.9x2.5, Simple rod, Fictitious eccentricity



Matte.	A1	A2	A3	I2	I3
1 - Aluminum	1.920e-4	9.577e-5	9.577e-5	11 2.881e-8	1.440e-8

Set: 8 Section: D=26.9x2.5, Simple rod, Fictitious eccentricity



Matte.	A1	A2	A3	I2	I3
1 - Aluminum	1.920e-4	9.577e-5	9.577e-5	11 2.881e-8	1.440e-8

Beam contours Set 1. D= 88.9x6

No	Node I	Node J	Releasing influence												M	Position mark			
			Node I						Node J										
			M1	M2	M3	P	P2	P3	M1	M2	M3	P1	P2	P3					
		12																	
12		33																	
3		38																	
4		45																	
5		63																	
6		72																	
7		75																	
8		93																	
9		105																	

Beam contours Set 2. D= 76.1x5

No	Node I	Node J	Releasing influence												M	Position mark			
			Node I						Node J										
			M1	M2	M3	P	P2	P3	M1	M2	M3	P1	P2	P3					
1		98																	
2		123																	
3		132																	
4		135																	
5		153																	
6		158																	
7		165																	
8		183																	
9		195																	

Beam contours Set 3. D= 60.3x4

No	Node I	Node J	Releasing influence												M	Position mark			
			Node I						Node J										
			M1	M2	M3	P	P2	P3	M1	M2	M3	P1	P2	P3					
		192																	
12		213																	
3		218																	
4		225																	
5		243																	
6		252																	
7		255																	
8		273																	
9		285																	

Beam contours Set 4. D= 33.7x3

No	Node I	Node J	Releasing influence												M	Position mark			
			Node I						Node J										
			M1	M2	M3	P	P2	P3	M1	M2	M3	P1	P2	P3					
1		278																	
2		303																	
3		312																	
4		315																	
5		333																	
6		338																	
7		345																	
8		359																	
9		363																	

Beam contours Set 5. D= 26.9x2.5

No	Node I	Node J	Releasing influence												M	Position mark			
			Node I						Node J										
			M1	M2	M3	P	P2	P3	M1	M2	M3	P1	P2	P3					
		45																	
12		1																	
3		6																	
4		6																	
5		12																	
6		12																	
7		33																	
8		38																	
9		38																	
10		38																	
11		45																	
12		45																	
13		63																	
14		63																	
15		63																	

16	72	93																
17	72	105																
18	93	105																

Beam contours Set 6. D= 26.9x2.5

No	Node I	Node J	Releasing influence												M	Position mark									
			Node I						Node J																
			M1	M2	M3	P1	P2	P3	M1	M2	M3	P1	P2	P3											
		72																							
1 2	98	123																							
3	98	135																							
4	98	165																							
5	105	98																							
6	105	123																							
7	123	132																							
8	123	135																							
9	123	165																							
10	132	153																							
11	132	165																							
12	132	183																							
13	153	165																							
14	158	183																							
15	158	195																							
16	165	158																							
17	165	183																							
18	183	195																							

Beam contours Set 7. D= 26.9x2.5

No	Node I	Node J	Releasing influence												M	Position mark										
			Node I						Node J																	
			M1	M2	M3	P1	P2	P3	M1	M2	M3	P1	P2	P3												
		158																								
1	183	192																								
2 3	183	225																								
4	192	213																								
5	192	225																								
6	192	243																								
7	213	225																								
8	218	243																								
9	218	255																								
10	218	285																								
11	225	218																								
12	225	243																								
13	243	252																								
14	243	255																								
15	243	285																								
16	252	273																								
17	252	285																								
18	273	285																								

Beam contours Set 8. D= 26.9x2.5

No	Node I	Node J	Releasing influence												M	Position mark										
			Node I						Node J																	
			M1	M2	M3	P1	P2	P3	M1	M2	M3	P1	P2	P3												
		252																								
1	278	303																								
2	278	303																								
3	278	315																								
4	278	345																								
5	285	278																								
6	285	303																								
7	303	312																								
8	303	315																								
9	303	345																								
10	312	333																								
11	312	345																								
12	312	359																								
13	333	345																								
14	338	359																								
15	338	363																								
16	345	338																								
17	345	359																								
18	359	363																								


Contours of point supports

Nodes	Set
1, 6, 15	1

List of load cases


LC	Name	pX [kN]	pY [kN]	pZ [kN]
	constantv (g)	-0.00	-10.00	-1.31
1 2	Comb.: 1.35x1	-0.00	-13.50	-1.76
3	Comb.: 1	-0.00	-10.00	-1.31

Charge 1: constant (g)




Level: [12.00 m]


Dimensioning (steel)



Frame: H_1
Stability control




Ram: K_1
Kontrola stabilnosti



STICK 38-72
 CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



($f_y = 12.5 \text{ kN/cm}^2$, $f_u = 18.5 \text{ kN/cm}^2$)

$A_x =$	16.630 cm ²
$A_y =$	7.809 cm ²
$A_z =$	7.809 cm ²
$I_x =$	269.75 cm ⁴
$I_y =$	134.94 cm ⁴
$I_{From -}$	134.94 cm ⁴
$W_y =$	30.358 cm ³
$W_z =$	30.358 cm ³
$W_{y,pl} =$	41.306 cm ³
$W_{z,pl} =$	41.306 cm ³
$\bar{y}M0 =$	1.000
$\bar{y}M1 =$	1.000
$\bar{y}M2 =$	1.000
$A_{net}/A =$	0.900


[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS
 3. $\bar{y}=0.32$

A ROD EXPOSED TO CENTRAL PRESSURE
 (load case 3, end of rod)

ROD 12-38
 CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



($f_y = 12.5 \text{ kN/cm}^2$, $f_u = 18.5 \text{ kN/cm}^2$)

$A_x =$	16.630 cm ²
$A_y =$	7.809 cm ²
$A_z =$	7.809 cm ²
$I_x =$	269.75 cm ⁴
$I_y =$	134.94 cm ⁴
$I_{From -}$	134.94 cm ⁴
$W_y =$	30.358 cm ³
$W_z =$	30.358 cm ³
$W_{y,pl} =$	41.306 cm ³
$W_{z,pl} =$	41.306 cm ³
$\bar{y}M0 =$	1.000
$\bar{y}M1 =$	1.000
$\bar{y}M2 =$	1.000
$A_{net}/A =$	0.900

[m m]

Calculation normal force	NO =	-65.272 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure Condition 6.9: $N_{Ed} \leq N_{c,Rd} (65.27 \leq 207.88)$

$N_{c,Rd} = 207.88 \text{ kN}$

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length y_y

Relative slenderness y_y

Buckling curve for axis y_y : A

Elastic critical force

Reduction coefficient

Calculated buckling resistance Condition 6.46: $N_{Ed} \leq N_{b,Rd,y} (65.27 \leq 204.51)$

$I_y =$	100.00 cm
$\bar{y}_y = \bar{y}$	0.273
\bar{y}	0.210
$N_{cr,y} =$	2796.8 kN
$\bar{y}_y =$	0.984
$N_{b,Rd,y} =$	204.51 kN

Buckling length z_z

Relative slenderness of the z_z

Buckling curve for axis z_z : A

Reduction coefficient

Calculation resistance to buckling

Condition 6.46: $N_{Ed} \leq N_{b,Rd,z} (65.27 \leq 204.51)$

$I_z =$	100.00 cm
$\bar{y}_z =$	0.273
\bar{y}	0.210
$\bar{y}_z =$	0.984
$N_{b,Rd,z} =$	204.51 kN

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.39$

A ROD EXPOSED TO CENTRAL PRESSURE
 (load case 3, end of rod)

Calculation normal force	NO =	-79.762 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure Condition 6.9: $N_{Ed} \leq N_{c,Rd} (79.76 \leq 207.88)$

$N_{c,Rd} = 207.88 \text{ kN}$

6.3 ELEMENTS BUCKLING CAPACITY 6.3.1.1 Buckling

capacity Buckling length y_y

Relative slenderness y_y

Buckling curve for axis y_y : A

Elastic critical force

Reduction coefficient

Calculated buckling resistance

$I_y =$	100.00 cm
$\bar{y}_y =$	0.273
\bar{y}	0.210
$N_{cr,y} =$	2796.8 kN
$\bar{y}_y =$	0.984
$N_{b,Rd,y} =$	204.51 kN

Condition 6.46: $NEd \leq Nb,Rd,y$ (79.76 \leq 204.51)

Buckling length zz
Relative slenderness of the zz
Buckling curve for axis zz: A

$l_z = 100.00$ cm
 $\bar{y}_z = 0.273$
 $\bar{y} = 0.210$


Reduction coefficient
Calculation resistance to buckling
Condition 6.46: $NEd \leq Nb,Rd,z$ (79.76 \leq 204.51)

$\bar{y}_z = 0.984$
 $Nb,Rd,z = 204.51$ kN

ROD 1-12

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 16.630$ cm²
 $A_y = 7.809$ cm²
 $A_z = 7.809$ cm²
 $I_x = 269.75$ cm⁴
 $I_y = 134.94$ cm⁴
 $I_{z,From} = 134.94$ cm⁴
 $W_y = 30.358$ cm³
 $W_z = 30.358$ cm³
 $W_{y,pl} = 41.306$ cm³
 $W_{z,pl} = 41.306$ cm³
 $\bar{y}M_0 = 1.000$
 $\bar{y}M_1 = 1.000$
 $\bar{y}M_2 = 1.000$
 $A_{net}/A = 0.900$

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y} = 0.39$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force

NO = -79.818 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure
Condition 6.9: $NEd \leq Nc,Rd$ (79.82 \leq 207.88)

$Nc,Rd = 207.88$ kN

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length yy**

Relative slenderness yy

$l_y = 100.00$ cm

Buckling curve for axis

$\bar{y}_y = 0.273$

yy: A **Elastic critical force**

$\bar{y} = 0.210$

Reduction coefficient

$Ncr,y = 2796.8$ kN

Calculated resistance to buckling

$\bar{y}_y = 0.984$

Condition 6.46: $NEd \leq Nb,Rd,y$ (79.82 \leq 204.51)

$Nb,Rd,y = 204.51$ kN

Buckling length zz

$l_z = 100.00$ cm

Relative slenderness zz

$\bar{y}_z = 0.273$

Buckling curve for axis zz: A

$\bar{y} = 0.210$

Reduction coefficient

$\bar{y}_z = 0.984$

Calculated resistance to buckling


$Nb,Rd,z = 204.51$ kN

Condition 6.46: $NEd \leq Nb,Rd,z$ (79.82 \leq 204.51)

ROD 33-63

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 16.630$ cm²
 $A_y = 7.809$ cm²
 $A_z = 7.809$ cm²
 $I_x = 269.75$ cm⁴
 $I_y = 134.94$ cm⁴
 $I_{z,From} = 134.94$ cm⁴
 $W_y = 30.358$ cm³
 $W_z = 30.358$ cm³
 $W_{y,pl} = 41.306$ cm³
 $W_{z,pl} = 41.306$ cm³
 $\bar{y}M_0 = 1.000$
 $\bar{y}M_1 = 1.000$
 $\bar{y}M_2 = 1.000$
 $A_{net}/A = 0.900$

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y} = 0.39$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force

NO = -79.765 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure
Condition 6.9: $NEd \leq Nc,Rd$ (79.77 \leq 207.88)

$Nc,Rd = 207.88$ kN

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length yy**

Relative slenderness yy

$l_y = 100.00$ cm

Buckling curve for axis

$\bar{y}_y = \bar{y} = 0.273$

yy: A **Elastic critical force**

$\bar{y} = 0.210$

Reduction coefficient

$Ncr,y = 2796.8$ kN

Calculated resistance to buckling

$\bar{y}_y = 0.984$

Condition 6.46: $NEd \leq Nb,Rd,y$ (79.77 \leq 204.51)

$Nb,Rd,y = 204.51$ kN

Buckling length zz

$l_z = 100.00$ cm

Relative slenderness zz

$\bar{y}_z = 0.273$

Buckling curve for axis zz: A

$\bar{y} = 0.210$

Reduction coefficient

$\bar{y}_z = 0.984$

Calculated buckling resistance


$Nb,Rd,z = 204.51$ kN

Condition 6.46: $NEd \leq Nb,Rd,z$ (79.77 \leq 204.51)

ROD 6-33

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 16.630$ cm²
 $A_y = 7.809$ cm²
 $A_z = 7.809$ cm²
 $I_x = 269.75$ cm⁴
 $I_y = 134.94$ cm⁴
 $I_{z,From} = 134.94$ cm⁴
 $W_y = 30.358$ cm³
 $W_z = 30.358$ cm³
 $W_{y,pl} = 41.306$ cm³
 $W_{z,pl} = 41.306$ cm³
 $\bar{y}M_0 = 1.000$
 $\bar{y}M_1 = 1.000$
 $\bar{y}M_2 = 1.000$
 $A_{net}/A = 0.900$

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y} = 0.39$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force

NO = -79.814 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure
Condition 6.9: $NEd \leq Nc,Rd$ (79.81 \leq 207.88)

$Nc,Rd = 207.88$ kN

6.3 LOAD CAPACITY OF ELEMENTS AGAINST BULLION

6.3.1.1 Buckling capacity **Buckling**

length yy Relative

$l_y = 100.00$ cm

slenderness yy Buckling

$\bar{y}_y = \bar{y} = 0.273$

curve for axis yy: A **Elastic critical**

$\bar{y} = 0.210$

force

$Ncr,y = 2796.8$ kN

Reduction coefficient

$\bar{y}_y = 0.984$

Calculation resistance to buckling

$Nb,Rd,y = 204.51$ kN

Condition 6.46: $NEd \leq Nb,Rd,y$ (79.81 \leq 204.51)

Buckling length zz

$l_z = 100.00$ cm

Relative slenderness zz

$\bar{y}_z = \bar{y} = 0.273$

Buckling curve for axis zz: A

$\bar{y} = 0.210$

Reduction coefficient

$\bar{y}_z = 0.984$

Calculated buckling resistance


$Nb,Rd,z = 204.51$ kN

Condition 6.46: $NEd \leq Nb,Rd,z$ (79.81 \leq 204.51)

STICK 338-345

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy.pl =	1,494 cm ³
Wz.pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.39$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, end of rod)

Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS


6.2.3 Tension		
Plastic calculated resistance of gross section Limit calculated	Npl,Rd =	24,000 kN
resistance of net section Calculated resp. for	Nu,Rd =	28,771 kN
Condition 6.5: $NEd \leq Nt,Rd$ (9.24 \leq 24.00)	Nt,Rd =	24,000 kN

STICK 345-278

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]

EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy.pl =	1,494 cm ³
Wz.pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

Calculation normal force	NO =	-9.245 kN
System rod length	L =	128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculation resistance to pressure	Nc,Rd =	24,000 kN
Condition 6.9: $NEd \leq Nc,Rd$ (9.24 \leq 24.00)		

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy Relative slenderness yy	Iy =	128.06 cm
curve for axis yy: A	$\bar{\gamma}_y = \bar{\gamma}$	1.148
Elastic critical force	=	0.210
Reduction coefficient	Ncr,y =	18,199 kN
Calculated resistance to buckling	$\bar{\gamma}_y$	0.563
Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 \leq 13.52)	Nb,Rd,y =	13,522 kN

Buckling length zz	Iz =	128.06 cm
Relative slenderness zz	$\bar{\gamma}_z$	1.148
Buckling curve for axis zz: A	$\bar{\gamma}$	0.210
Reduction coefficient	$\bar{\gamma}_z$	0.563
Calculated buckling resistance	Nb,Rd,z =	13,522 kN
Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 \leq 13.52)		

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, beginning of the rod)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.39$

ROD EXPOSED TO CENTRIC TENSION


(load case 3, end of rod)

Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tension		
Plastic calculated resistance of gross section Limit calculated	Npl,Rd =	24,000 kN
resistance of net section Calculated resp. for	Nu,Rd =	28,771 kN
Condition 6.5: $NEd \leq Nt,Rd$ (9.24 \leq 24.00)	Nt,Rd =	24,000 kN

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy.pl =	1,494 cm ³
Wz.pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)


[m m]

STICK 285-218

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]

EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy.pl =	1,494 cm ³
Wz.pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

Calculation normal force	NO =	-9.245 kN
System rod length	L =	128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculation resistance to pressure	Nc,Rd =	24,000 kN
Condition 6.9: $NEd \leq Nc,Rd$ (9.24 \leq 24.00)		

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy	Iy =	128.06 cm
Relative slenderness yy	$\bar{\gamma}_y$	1.148
Buckling curve for axis yy: A	$\bar{\gamma}$	0.210
Elastic critical force	Ncr,y =	18,199 kN
Reduction coefficient	$\bar{\gamma}_y$	0.563
Calculated resistance to buckling	Nb,Rd,y =	13,522 kN
Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 \leq 13.52)		

Buckling length zz	Iz =	128.06 cm
Relative slenderness zz	$\bar{\gamma}_z$	1.148
Buckling curve for axis zz: A	$\bar{\gamma}$	0.210
Reduction coefficient	$\bar{\gamma}_z$	0.563
Calculated buckling resistance	Nb,Rd,z =	13,522 kN
Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 \leq 13.52)		

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.68$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, beginning of the rod)

ROD 218-225

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From-}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900


(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

STICK 225-158

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From-}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]


UTILIZATION FACTORS BY LOAD COMBINATIONS 3. $\bar{y}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE
 (load case 3, beginning of the rod)

STICK 158-165

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From-}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

STICK 165-98

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
 EUROCODE 3 (EN 1993-1-1:2005)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.39$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, end of rod)

Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tension

Plastic resistance of the gross cross-section Limit resistance of the net cross-

Npl,Rd =	24,000 kN
Nu,Rd =	28,771 kN

section Comput. for tensioning

Nt,Rd =	24,000 kN
---------	-----------

Condition 6.5: NEd <= Nt,Rd (9.24 <= 24.00)

Calculation normal force

NO =	-9.245 kN
------	-----------

System rod length

L =	128.06 cm
-----	-----------

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd =	24,000 kN
---------	-----------

Condition 6.9: NEd <= Nc,Rd (9.24 <= 24.00)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length yy**

ly =	128.06 cm
------	-----------

Relative slenderness yy

$\bar{y}_y = \bar{y}$	1.148
-----------------------	-------

Buckling curve for axis

\bar{y}	0.210
-----------	-------

yy: A **Elastic critical force**

Ncr,y =	18,199 kN
---------	-----------

Reduction coefficient

\bar{y}_y	0.563
-------------	-------

Calculated resistance to buckling Condition 6.46: NEd <=

Nb,Rd,y =	13,522 kN
-----------	-----------

Nb,Rd,y (9.24 <= 13.52)

Buckling length zz

lz =	128.06 cm
------	-----------

Relative slenderness of the zz

\bar{y}_z	1.148
-------------	-------

Buckling curve for axis zz: A

\bar{y}	0.210
-----------	-------

Reduction coefficient

\bar{y}_z	0.563
-------------	-------

Calculation resistance to buckling

Nb,Rd,z =	13,522 kN
-----------	-----------

Condition 6.46: NEd <= Nb,Rd,z (9.24 <= 13.52)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.39$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, end of rod)

Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tension

Plastic calculated resistance of gross section Limit calculated


Npl,Rd =	24,000 kN
Nu,Rd =	28,771 kN

resistance of net section

Nt,Rd =	24,000 kN
---------	-----------

Calculated resp. for tensioning Condition 6.5: NEd <= Nt,Rd (9.24 <= 24.00)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From-}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS 3. $\bar{y}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, beginning of the rod)

Calculation normal force	NO =	-9,245 kN
System rod length	L =	128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS
Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure	Nc,Rd =	24,000 kN
------------------------------------	---------	-----------

Condition 6.9: $NEd \leq Nc,Rd$ (9.24 <= 24.00)

6.3 LOAD CAPACITY OF ELEMENTS AGAINST BULLION
6.3.1.1 Buckling resistance


Bending length yy $I_y = 128.06$ cm
Relative slenderness yy $\bar{\lambda}_y = 1.148$
Buckling curve for the yy axis: A $\bar{\lambda} = 0.210$
Elastic critical force $N_{cr,y} = 18.199$ kN
Reduction coefficient $\bar{\chi}_y = 0.563$
Calculation resistance to buckling $Nb,Rd,y = 13.522$ kN
Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 <= 13.52)

Buckling length zz $I_z = 128.06$ cm
Relative slenderness of the zz $\bar{\lambda}_z = 1.148$
Buckling curve for axis zz: A $\bar{\lambda} = 0.210$
Reduction coefficient $\bar{\chi}_z = 0.563$
Calculation resistance to buckling $Nb,Rd,z = 13.522$ kN
Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 <= 13.52)

STICK 98-105

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
Iz =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{\gamma} = 0.39$

ROD EXPOSED TO CENTRIC TENSION
(load case 3, end of rod)

Calculation normal force	NO =	9,245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tension


Plastic calculated resistance of gross section Limit calculated	Npl,Rd =	24,000 kN
	Nu,Rd =	28,771 kN

resistance of net section $Nt,Rd = 24,000$ kN
Calculated resp. for tensioning Condition 6.5: $NEd \leq Nt,Rd$ (9.24 <= 24.00)

ROD 105-38

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
Iz =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Calculation normal force	NO =	-9,245 kN
System rod length	L =	128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS
Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure	Nc,Rd =	24,000 kN
------------------------------------	---------	-----------

Condition 6.9: $NEd \leq Nc,Rd$ (9.24 <= 24.00)

6.3 LOAD CAPACITY OF ELEMENTS AGAINST BULLION

6.3.1.1 Buckling capacity

Buckling length yy Relative slenderness yy	$I_y = 128.06$ cm
Buckling curve for axis yy: A	$\bar{\lambda}_y = 1.148$
Elastic critical force	$\bar{\lambda} = 0.210$
Reduction coefficient	$N_{cr,y} = 18.199$ kN
Calculation resistance to buckling	$\bar{\chi}_y = 0.563$
Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 <= 13.52)	$Nb,Rd,y = 13.522$ kN

Buckling length zz $I_z = 128.06$ cm
Relative slenderness zz $\bar{\lambda}_z = 1.148$
Buckling curve for axis zz: A $\bar{\lambda} = 0.210$
Reduction coefficient $\bar{\chi}_z = 0.563$
Calculated buckling resistance $Nb,Rd,z = 13.522$ kN
Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 <= 13.52)


UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{\gamma} = 0.68$

A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, beginning of the rod)

STICK 38-45

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
Iz =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{\gamma} = 0.39$

ROD EXPOSED TO CENTRIC TENSION
(load case 3, end of rod)

Calculation normal force	NO =	9,245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tension


Plastic calculated resistance of gross section Limit calculated	Npl,Rd =	24,000 kN
	Nu,Rd =	28,771 kN

resistance of net section $Nt,Rd = 24,000$ kN
Calculated resp. for tensioning Condition 6.5: $NEd \leq Nt,Rd$ (9.24 <= 24.00)

STICK 45-1

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
y _{M0} =	1,000
y _{M1} =	1,000
y _{M2} =	1,000
Anet/A =	0,900

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE


(load case 3, beginning of the rod)

Calculation normal force	NO =	-9.245 kN
--------------------------	------	-----------

STICK 359-312

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)


Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
y _{M0} =	1,000
y _{M1} =	1,000
y _{M2} =	1,000
Anet/A =	0,900

[m m]

STICK 312-303

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)


Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
y _{M0} =	1,000
y _{M1} =	1,000
y _{M2} =	1,000
Anet/A =	0,900

[m m]

STICK 303-252

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
y _{M0} =	1,000
y _{M1} =	1,000
y _{M2} =	1,000
Anet/A =	0,900

[m m]

System rod length

L = 128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

N_{c,Rd} = 24,000 kNCondition 6.9: NEd ≤ N_{c,Rd} (9.24 ≤ 24.00)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

l_y = 128.06 cm

Buckling curve for axis yy

y_y = 1.148

yy: A Elastic critical force

y = 0.210

Reduction coefficient

N_{cr,y} = 18.199 kN

Calculated resistance to buckling Condition 6.46: NEd ≤

y_y = 0.563

Nb,Rd,y (9.24 ≤ 13.52)

Nb,Rd,y = 13.522 kN

Buckling length zz

Relative slenderness zz

l_z = 128.06 cm

Buckling curve for axis zz: A

y_z = 1.148

Reduction coefficient

y = 0.210

Calculated buckling resistance

y_z = 0.563

Condition 6.46: NEd ≤ Nb,Rd,z (9.24 ≤ 13.52)

Nb,Rd,z = 13.522 kN

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$

No influence

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$

No influence

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 252-243

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 243-192

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 192-183

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 183-132

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 132-123

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

STICK 123-72

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 72-63

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 63-12

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)


UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$

No influence

STICK 12-6

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)



$A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{y,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M_0 = 1,000$

($f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2$)

$\bar{y}M_1 = 1,000$
 $\bar{y}M_2 = 1,000$
 $A_{net}/A = 0,900$

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.00$


No influence

STICK 359-345

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{y,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M_0 = 1,000$
 $\bar{y}M_1 = 1,000$
 $\bar{y}M_2 = 1,000$
 $A_{net}/A = 0,900$

($f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2$)

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.39$

ROD EXPOSED TO CENTRIC TENSION
(load case 3, end of rod)

Calculation normal force NO = 9.245 kN
 System rod length L = 128.06 cm


6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile
Plastic resistance of the gross cross-section Limit resistance of the net cross-section Comput. for tensioning
Condition 6.5: $NEd \leq Nt,Rd (9.24 \leq 24.00)$
 $N_{pl,Rd} = 24,000 \text{ kN}$
 $N_{u,Rd} = 28,771 \text{ kN}$
 $N_{t,Rd} = 24,000 \text{ kN}$

STICK 345-303

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{y,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M_0 = 1,000$
 $\bar{y}M_1 = 1,000$
 $\bar{y}M_2 = 1,000$
 $A_{net}/A = 0,900$

($f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2$)

[m m]

Calculation normal force NO = -9.245 kN
 System rod length L = 128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure
Calculation resistance to pressure
Condition 6.9: $NEd \leq Nc,Rd (9.24 \leq 24.00)$
 $N_{c,Rd} = 24,000 \text{ kN}$

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length yy**
 Relative slenderness yy $\bar{y}_y = 1.148$
 Buckling curve for axis yy: A **Elastic critical force**
 Reduction coefficient $\eta_{cr,y} = 0.210$
Calculated resistance to buckling Condition 6.46: $NEd \leq Nb,Rd,y (9.24 \leq 13.52)$
 $N_{cr,y} = 18,199 \text{ kN}$
 $\bar{y}_y = 0.563$
 $N_{b,Rd,y} = 13,522 \text{ kN}$

Buckling length zz
 Relative slenderness zz $\bar{y}_z = 1.148$
 Buckling curve for axis zz: A $\bar{y}_z = 0.210$
 Reduction coefficient = 0.563
Calculated buckling resistance
Condition 6.46: $NEd \leq Nb,Rd,z (9.24 \leq 13.52)$
 $N_{b,Rd,z} = 13,522 \text{ kN}$


UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, beginning of the rod)

STICK 303-285

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{y,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M_0 = 1,000$
 $\bar{y}M_1 = 1,000$
 $\bar{y}M_2 = 1,000$
 $A_{net}/A = 0,900$

($f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2$)

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.39$

ROD EXPOSED TO CENTRIC TENSION
(load case 3, end of rod)

Calculation normal force NO = 9.245 kN
 System rod length L = 128.06 cm


6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile
Plastic resistance of the gross cross-section Limit resistance of the net cross-section Comput. for tensioning
Condition 6.5: $NEd \leq Nt,Rd (9.24 \leq 24.00)$
 $N_{pl,Rd} = 24,000 \text{ kN}$
 $N_{u,Rd} = 28,771 \text{ kN}$
 $N_{t,Rd} = 24,000 \text{ kN}$

STICK 285-243

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M0$	=	1,000
$\bar{y}M1$	=	1,000
$\bar{y}M2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE


(load case 3, beginning of the rod)

Calculation normal force	NO =	-9.245 kN
--------------------------	------	-----------

STICK 243-225

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS




A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M0$	=	1,000
$\bar{y}M1$	=	1,000
$\bar{y}M2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

STICK 225-183

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M0$	=	1,000
$\bar{y}M1$	=	1,000
$\bar{y}M2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, beginning of the rod)

STICK 183-165

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

System rod length

L = 128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 24,000 kN

Condition 6.9: $NEd \leq Nc,Rd$ (9.24 \leq 24.00)

6.3 BUCKLING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

 $\bar{\lambda}_y$ = 1.148

Buckling curve for axis yy

 $\bar{\gamma}_y$ = 0.210

yy: A Elastic critical force

Ncr,y = 18.199 kN

Reduction coefficient

 $\bar{\chi}_y$ = 0.563

Calculated resistance to buckling

Nb,Rd,y = 13.522 kN

Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 \leq 13.52)

Buckling length zz

 $\bar{\lambda}_z$ = 1.148

Relative slenderness zz

 $\bar{\gamma}_z$ = 0.210

Buckling curve for axis zz: A

 $\bar{\gamma}_z$ = 0.210

Reduction coefficient

 $\bar{\chi}_z$ = 0.563

Calculated buckling resistance

Nb,Rd,z = 13.522 kN

Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 \leq 13.52)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.39$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, end of rod)

Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile

Plastic resistance of the gross cross-section

Npl,Rd = 24,000 kN

Limit resistance of the

Nu,Rd = 28,771 kN

net cross-

section Comput. for tensioning

Nt,Rd = 24,000 kN

Condition 6.5: $NEd \leq Nt,Rd$ (9.24 \leq 24.00)

Calculation normal force

NO = -9.245 kN

System rod length

L = 128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 24,000 kN

Condition 6.9: $NEd \leq Nc,Rd$ (9.24 \leq 24.00)

6.3 BUCKLING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity Buckling length

yy Relative slenderness

 $\bar{\lambda}_y$ = 1.148

yy Buckling curve for axis

 $\bar{\gamma}_y$ = 0.210

yy: A Elastic critical force

Ncr,y = 18.199 kN

Reduction coefficient

 $\bar{\chi}_y$ = 0.563

Calculation resistance to buckling

Nb,Rd,y = 13.522 kN

Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 \leq 13.52)

Buckling length zz

 $\bar{\lambda}_z$ = 1.148

Relative slenderness of the zz

 $\bar{\gamma}_z$ = 0.210

Buckling curve for axis zz: A

 $\bar{\gamma}_z$ = 0.210

Reduction coefficient


 $\bar{\chi}_z$ = 0.563

Calculation resistance to buckling

Nb,Rd,z = 13.522 kN

Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 \leq 13.52)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M0$	=	1,000
$\bar{y}M1$	=	1,000
$\bar{y}M2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.39$

ROD EXPOSED TO CENTRIC TENSION
(load case 3, end of rod)


Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

STICK 165-123

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)


UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, beginning of the rod)

STICK 123-105

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS




Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

ROD 105-63

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From -}	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.68$

A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, beginning of the rod)

STICK 359-338

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

6.2.3 Tensile

Plastic resistance of the gross cross-section
Limit resistance of the net cross-section Comput. for tensioning
Condition 6.5: $NEd \leq Nt,Rd$ (9.24 \leq 24.00)

Npl,Rd =	24,000 kN
Nu,Rd =	28,771 kN
Nt,Rd =	24,000 kN

Calculation normal force

NO =	-9.245 kN
System rod length	L = 128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure
Condition 6.9: $NEd \leq Nc,Rd$ (9.24 \leq 24.00)

Nc,Rd =	24,000 kN
---------	-----------

6.3 LOAD CAPACITY OF ELEMENTS AGAINST BULLION

6.3.1.1 Buckling capacity

Buckling length yy Relative slenderness yy Buckling curve for axis yy: A Elastic critical force

ly =	128.06 cm
$\bar{y}_y = \bar{y}$	1.148
=	0.210
Ncr,y =	18,199 kN
\bar{y}_y	0.563
Nb,Rd,y =	13,522 kN

Reduction coefficient
Calculated buckling resistance
Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 \leq 13.52)

Buckling length zz

Relative slenderness of the zz
Buckling curve for axis zz: A
Reduction coefficient

lz =	128.06 cm
\bar{y}_z	1.148
\bar{y}	0.210
\bar{y}_z	0.563
Nb,Rd,z =	13,522 kN

Calculated resistance to buckling
Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 \leq 13.52)

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.39$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, end of rod)

Calculation normal force	NO =	9.245 kN
System rod length	L =	128.06 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile

Plastic resistance of the gross cross-section
Limit resistance of the net cross-section Comput. for tensioning
Condition 6.5: $NEd \leq Nt,Rd$ (9.24 \leq 24.00)

Npl,Rd =	24,000 kN
Nu,Rd =	28,771 kN
Nt,Rd =	24,000 kN

Calculation normal force

NO =	-9.245 kN
System rod length	L = 128.06 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure
Condition 6.9: $NEd \leq Nc,Rd$ (9.24 \leq 24.00)

Nc,Rd =	24,000 kN
---------	-----------

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity

Buckling length yy

Relative slenderness yy

Buckling curve for axis yy: A Elastic critical force

Reduction coefficient

Calculated resistance to buckling
Condition 6.46: $NEd \leq Nb,Rd,y$ (9.24 \leq 13.52)

ly =	128.06 cm
$\bar{y}_y = \bar{y}$	1.148
=	0.210
Ncr,y =	18,199 kN
\bar{y}_y	0.563
Nb,Rd,y =	13,522 kN

Buckling length zz

Relative slenderness zz


Buckling curve for axis zz: A

Reduction coefficient

Calculated buckling resistance
Condition 6.46: $NEd \leq Nb,Rd,z$ (9.24 \leq 13.52)

lz =	128.06 cm
\bar{y}_z	1.148
\bar{y}	0.210
\bar{y}_z	0.563
Nb,Rd,z =	13,522 kN

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x =$	1,920 cm ²
$A_y =$	0,958 cm ²
$A_z =$	0,958 cm ²
$I_x =$	2,881 cm ⁴
$I_y =$	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
$W_y =$	1,071 cm ³
$W_z =$	1,071 cm ³
$W_{y,pl} =$	1,494 cm ³
$W_{z,pl} =$	1,494 cm ³
$\bar{y}M_0 =$	1,000

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

$\bar{y}M_1 =$	1,000
$\bar{y}M_2 =$	1,000
$A_{net}/A =$	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

STICK 333-312

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x =$	1,920 cm ²
$A_y =$	0,958 cm ²
$A_z =$	0,958 cm ²
$I_x =$	2,881 cm ⁴
$I_y =$	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
$W_y =$	1,071 cm ³
$W_z =$	1,071 cm ³
$W_{y,pl} =$	1,494 cm ³
$W_{z,pl} =$	1,494 cm ³
$\bar{y}M_0 =$	1,000
$\bar{y}M_1 =$	1,000
$\bar{y}M_2 =$	1,000
$A_{net}/A =$	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 303-278

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x =$	1,920 cm ²
$A_y =$	0,958 cm ²
$A_z =$	0,958 cm ²
$I_x =$	2,881 cm ⁴
$I_y =$	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
$W_y =$	1,071 cm ³
$W_z =$	1,071 cm ³
$W_{y,pl} =$	1,494 cm ³
$W_{z,pl} =$	1,494 cm ³
$\bar{y}M_0 =$	1,000
$\bar{y}M_1 =$	1,000
$\bar{y}M_2 =$	1,000
$A_{net}/A =$	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 273-252

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x =$	1,920 cm ²
$A_y =$	0,958 cm ²
$A_z =$	0,958 cm ²
$I_x =$	2,881 cm ⁴
$I_y =$	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
$W_y =$	1,071 cm ³
$W_z =$	1,071 cm ³
$W_{y,pl} =$	1,494 cm ³
$W_{z,pl} =$	1,494 cm ³
$\bar{y}M_0 =$	1,000
$\bar{y}M_1 =$	1,000
$\bar{y}M_2 =$	1,000
$A_{net}/A =$	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 243-218

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

STICK 213-192

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 183-158

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 153-132

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 123-98

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x =	1,920 cm ²
A_y =	0,958 cm ²
A_z =	0,958 cm ²
I_x =	2,881 cm ⁴
I_y =	1,440 cm ⁴
I_{From-} =	1,440 cm ⁴
W_y =	1,071 cm ³
W_z =	1,071 cm ³
$W_{y,pl}$ =	1,494 cm ³
$W_{z,pl}$ =	1,494 cm ³
$\bar{y}M_0$ =	1,000

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

$\bar{y}M_1$ =	1,000
$\bar{y}M_2$ =	1,000
A_{net}/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

STICK 93-72

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x =	1,920 cm ²
A_y =	0,958 cm ²
A_z =	0,958 cm ²
I_x =	2,881 cm ⁴
I_y =	1,440 cm ⁴
I_{From-} =	1,440 cm ⁴
W_y =	1,071 cm ³
W_z =	1,071 cm ³
$W_{y,pl}$ =	1,494 cm ³
$W_{z,pl}$ =	1,494 cm ³
$\bar{y}M_0$ =	1,000
$\bar{y}M_1$ =	1,000
$\bar{y}M_2$ =	1,000
A_{net}/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 63-38

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x =	1,920 cm ²
A_y =	0,958 cm ²
A_z =	0,958 cm ²
I_x =	2,881 cm ⁴
I_y =	1,440 cm ⁴
I_{From-} =	1,440 cm ⁴
W_y =	1,071 cm ³
W_z =	1,071 cm ³
$W_{y,pl}$ =	1,494 cm ³
$W_{z,pl}$ =	1,494 cm ³
$\bar{y}M_0$ =	1,000
$\bar{y}M_1$ =	1,000
$\bar{y}M_2$ =	1,000
A_{net}/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 33-12

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x =	1,920 cm ²
A_y =	0,958 cm ²
A_z =	0,958 cm ²
I_x =	2,881 cm ⁴
I_y =	1,440 cm ⁴
I_{From-} =	1,440 cm ⁴
W_y =	1,071 cm ³
W_z =	1,071 cm ³
$W_{y,pl}$ =	1,494 cm ³
$W_{z,pl}$ =	1,494 cm ³
$\bar{y}M_0$ =	1,000
$\bar{y}M_1$ =	1,000
$\bar{y}M_2$ =	1,000
A_{net}/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 363-359

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.29$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, beginning of the rod)

Calculation normal force NO = -5.774 kN

System rod length

L = 80,000 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 24,000 kN

Condition 6.9: NEd ≤ Nc,Rd (5.77 ≤ 24.00)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

l_y = 80,000 cm

Buckling curve for axis yy

 \bar{y}_y = 0.717

yy: A Elastic critical force

y = 0.210

Reduction coefficient

Ncr,y = 46.634 kN

Calculated resistance to buckling Condition 6.46: NEd ≤ Nb,Rd,y (5.77 ≤ 20.15)

 \bar{y}_y = 0.839

Nb,Rd,y = 20.146 kN

Buckling length zz

Relative slenderness zz

l_z = 80,000 cm

Buckling curve for axis zz: A

 \bar{y}_z = 0.717

Reduction coefficient

y = 0.210

Calculated buckling resistance

 \bar{y}_z = 0.839

Condition 6.46: NEd ≤ Nb,Rd,z (5.77 ≤ 20.15)


Nb,Rd,z = 20.146 kN

STICK 345-333

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]

EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

ROD 315-303

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]

EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

STICK 285-273

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]

EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 255-243

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

ROD 225-213

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 195-183

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 165-153

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 135-123

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	1,920 cm ²
A_y	0,958 cm ²
A_z	0,958 cm ²
I_x	2,881 cm ⁴
I_y	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
W_y	1,071 cm ³
W_z	1,071 cm ³
$W_{y,pl}$	1,494 cm ³
$W_{z,pl}$	1,494 cm ³
$\bar{y}M_0$	1,000

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

ROD 105-93

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	1,920 cm ²
A_y	0,958 cm ²
A_z	0,958 cm ²
I_x	2,881 cm ⁴
I_y	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
W_y	1,071 cm ³
W_z	1,071 cm ³
$W_{y,pl}$	1,494 cm ³
$W_{z,pl}$	1,494 cm ³
$\bar{y}M_0$	1,000
$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

ROD 75-63

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	1,920 cm ²
A_y	0,958 cm ²
A_z	0,958 cm ²
I_x	2,881 cm ⁴
I_y	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
W_y	1,071 cm ³
W_z	1,071 cm ³
$W_{y,pl}$	1,494 cm ³
$W_{z,pl}$	1,494 cm ³
$\bar{y}M_0$	1,000
$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 45-33

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	1,920 cm ²
A_y	0,958 cm ²
A_z	0,958 cm ²
I_x	2,881 cm ⁴
I_y	1,440 cm ⁴
I_{From-}	1,440 cm ⁴
W_y	1,071 cm ³
W_z	1,071 cm ³
$W_{y,pl}$	1,494 cm ³
$W_{z,pl}$	1,494 cm ³
$\bar{y}M_0$	1,000
$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 93-123

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy.pl =	25.318 cm ³
Wz.pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.48$

A ROD EXPOSED TO CENTRAL PRESSURE


(load case 3, end of rod)

Calculation normal force	NO =	-65,220 kN
--------------------------	------	------------

STICK 123-153

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy.pl =	25.318 cm ³
Wz.pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.37$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 153-183

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy.pl =	25.318 cm ³
Wz.pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.37$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 183-213

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
EUROCODE 3 (EN 1993-1-1:2005)

System rod length

L = 100,000 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Condition 6.9: NEd <= Nc,Rd (65.22 <= 139.63)

Nc,Rd = 139.63 kN

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

ly = 100,000 cm

Buckling curve for axis

 $\bar{\gamma}_{yy} = 0.308$ 0.210

yy: A Elastic critical force

 $\bar{\gamma} = 1469.9$

Reduction coefficient

Ncr,y = kN 0.976

Calculated buckling

 $\bar{\gamma}_{yy} = 136.21$

resistance Condition 6.46: NEd <=

Nb,Rd,y = kN

Nb,Rd,y (65.22 <= 136.21)

Buckling length zz

lz = 100,000 cm

Relative slenderness zz

 $\bar{\gamma}_{zz} = 0.308$ 0.210

Buckling curve for axis zz: A

 $\bar{\gamma} = 0.976$

Reduction coefficient

 $\bar{\gamma}_{zz} = 136.21$

Calculated buckling resistance

Nb,Rd,z = kN

Condition 6.46: NEd <= Nb,Rd,z (65.22 <= 136.21)

Calculation normal force

NO = -50.739 kN

System rod length

L = 100,000 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Condition 6.9: NEd <= Nc,Rd (50.74 <= 139.63)

Nc,Rd = 139.63 kN

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

ly = 100.00 cm

Buckling curve for axis

 $\bar{\gamma}_{yy} = 0.308$

yy: A Elastic critical force

 $\bar{\gamma} = 0.210$

Reduction coefficient

Ncr,y = 1469.9 kN

Calculated resistance to

 $\bar{\gamma}_{yy} = 0.976$

buckling Condition 6.46: NEd <=

Nb,Rd,y = 136.21 kN

Nb,Rd,y (50.74 <= 136.21)

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz} = 0.308$

Buckling curve for axis zz: A

 $\bar{\gamma} = 0.210$

Reduction coefficient

 $\bar{\gamma}_{zz} = 0.976$

Calculated buckling resistance

Nb,Rd,z = 136.21 kN

Condition 6.46: NEd <= Nb,Rd,z (50.74 <= 136.21)

Calculation normal force

NO = -50.704 kN

System rod length

L = 100,000 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Condition 6.9: NEd <= Nc,Rd (50.70 <= 139.63)

Nc,Rd = 139.63 kN

6.3 BURNING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity Buckling length

yy Relative slenderness

ly = 100.00 cm

yy Buckling curve for axis

 $\bar{\gamma}_{yy} = \bar{\gamma} = 0.308$

yy: A Elastic critical force

 $\bar{\gamma} = 0.210$

Reduction coefficient

Ncr,y = 1469.9 kN

Calculated buckling

 $\bar{\gamma}_{yy} = 0.976$

resistance Condition 6.46: NEd <=

Nb,Rd,y = 136.21 kN

Nb,Rd,y (50.70 <= 136.21)

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz} = 0.308$

Buckling curve for axis zz: A

 $\bar{\gamma} = 0.210$

Reduction coefficient


 $\bar{\gamma}_{zz} = 0.976$

Calculated buckling resistance

Nb,Rd,z = 136.21 kN

Condition 6.46: NEd <= Nb,Rd,z (50.70 <= 136.21)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	7,070 cm ²
Ay =	3,536 cm ²
Az =	3,536 cm ²
Ix =	56,317 cm ⁴
Iy =	28,170 cm ⁴
I _{From -}	28,170 cm ⁴
Wy =	9,343 cm ³
Wz =	9,343 cm ³
Wy.pl =	12,700 cm ³
Wz.pl =	12,700 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.43$

A ROD EXPOSED TO CENTRAL PRESSURE


(load case 3, end of rod)

Calculation normal force	NO =	-36.223 kN
--------------------------	------	------------

STICK 213-243

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	7,070 cm ²
Ay =	3,536 cm ²
Az =	3,536 cm ²
Ix =	56,317 cm ⁴
Iy =	28,170 cm ⁴
I _{From -}	28,170 cm ⁴
Wy =	9,343 cm ³
Wz =	9,343 cm ³
Wy.pl =	12,700 cm ³
Wz.pl =	12,700 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.43$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 243-273

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	7,070 cm ²
Ay =	3,536 cm ²
Az =	3,536 cm ²
Ix =	56,317 cm ⁴
Iy =	28,170 cm ⁴
I _{From -}	28,170 cm ⁴
Wy =	9,343 cm ³
Wz =	9,343 cm ³
Wy.pl =	12,700 cm ³
Wz.pl =	12,700 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.26$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 273-303

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

System rod length L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 88,375 kN

Condition 6.9: NEd <= Nc,Rd (36.22 <= 88.38)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length** yy

Relative slenderness yy

ly = 100.00 cm

Buckling curve for axis yy

 $\bar{\gamma}_{yy}$ = 0.389yy: A **Elastic critical force** $\bar{\gamma}$ = 0.210

Reduction coefficient

Ncr,yy = 583.86 kN

Calculated resistance to buckling

 $\bar{\gamma}_{yy}$ = 0.956

Condition 6.46: NEd <= Nb,Rd,yy

Nb,Rd,yy = 84.455 kN

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz}$ = 0.389

Buckling curve for axis zz: A

 $\bar{\gamma}$ = 0.210

Reduction coefficient

 $\bar{\gamma}_{zz}$ = 0.956

Calculated buckling resistance

Nb,Rd,zz = 84.455 kN

Condition 6.46: NEd <= Nb,Rd,zz (36.22 <= 84.45)

Calculation normal force

NO = -36.200 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated pressure resistance

Nc,Rd = 88,375 kN

Condition 6.9: NEd <= Nc,Rd (36.20 <= 88.38)

6.3 BURNING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity **Buckling length** yy

yy Relative slenderness

ly = 100.00 cm

yy Buckling curve for axis yy

 $\bar{\gamma}_{yy}$ = 0.389yy: A **Elastic critical force** $\bar{\gamma}$ = 0.210

Reduction coefficient

Ncr,yy = 583.86 kN

Calculated buckling

 $\bar{\gamma}_{yy}$ = 0.956

resistance Condition 6.46: NEd <= Nb,Rd,yy

Nb,Rd,yy = 84.455 kN

Nb,Rd,yy (36.20 <= 84.45)

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz}$ = 0.389

Buckling curve for axis zz: A

 $\bar{\gamma}$ = 0.210

Reduction coefficient

 $\bar{\gamma}_{zz}$ = 0.956

Calculated resistance to buckling

Nb,Rd,zz = 84.455 kN

Condition 6.46: NEd <= Nb,Rd,zz (36.20 <= 84.45)

Calculation normal force

NO = -21.730 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated resistance to pressure

Nc,Rd = 88,375 kN

Condition 6.9: NEd <= Nc,Rd (21.73 <= 88.38)

6.3 BURNING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity **Buckling length** yy

yy Relative slenderness

ly = 100.00 cm

yy Buckling curve for axis yy

 $\bar{\gamma}_{yy} = \bar{\gamma}$ = 0.389yy: A **Elastic critical force** $\bar{\gamma}$ = 0.210

Reduction coefficient

Ncr,yy = 583.86 kN

Calculated resistance to buckling

 $\bar{\gamma}_{yy}$ = 0.956

Condition 6.46: NEd <= Nb,Rd,yy

Nb,Rd,yy = 84.455 kN

Nb,Rd,yy (21.73 <= 84.45)

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz}$ = 0.389

Buckling curve for axis zz: A

 $\bar{\gamma}$ = 0.210

Reduction coefficient


 $\bar{\gamma}_{zz}$ = 0.956

Calculated buckling resistance

Nb,Rd,zz = 84.455 kN

Condition 6.46: NEd <= Nb,Rd,zz (21.73 <= 84.45)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.71$

A ROD EXPOSED TO CENTRAL PRESSURE


(load case 3, end of rod)

Calculation normal force	NO =	-21,706 kN
--------------------------	------	------------

STICK 303-333

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.24$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 333-359

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.24$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 363-338

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

System rod length L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 36,125 kN

Condition 6.9: NEd <= Nc,Rd (21.71 <= 36.13)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

ly = 100.00 cm

Buckling curve for axis

 $\bar{\gamma}_{yy}$ = 0.712

yy: A Elastic critical force

 $\bar{\gamma}$ = 0.210

Reduction coefficient

Ncr,y = 71.298 kN

Calculated resistance to buckling

 $\bar{\gamma}_{yy}$ = 0.842

Condition 6.46: NEd <= Nb,Rd,y

Nb,Rd,y = 30.422 kN

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz}$ = 0.712

Buckling curve for axis zz: A

 $\bar{\gamma}$ = 0.210

Reduction coefficient

 $\bar{\gamma}_{zz}$ = 0.842

Calculated buckling resistance

Nb,Rd,z = 30.422 kN

Condition 6.46: NEd <= Nb,Rd,z (21.71 <= 30.42)

Calculation normal force

NO = -7.247 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS Section

class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated resistance to pressure

Nc,Rd = 36,125 kN

Condition 6.9: NEd <= Nc,Rd (7.25 <= 36.13)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy Relative

slenderness yy Buckling

ly = 100.00 cm

curve for axis yy: A

 $\bar{\gamma}_{yy}$ = 0.712

Elastic critical force Reduction

 $\bar{\gamma}$ = 0.210

coefficient Calculated

Ncr,y = 71.298 kN

resistance to buckling

 $\bar{\gamma}_{yy}$ = 0.842

Condition 6.46: NEd <= Nb,Rd,y (7.25

Nb,Rd,y = 30.422 kN

<= 30.42)

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz}$ = 0.712

Buckling curve for axis zz: A

 $\bar{\gamma}$ = 0.210

Reduction coefficient

 $\bar{\gamma}_{zz}$ = 0.842

Calculated buckling resistance

Nb,Rd,z = 30.422 kN

Condition 6.46: NEd <= Nb,Rd,z (7.25 <= 30.42)

Calculation normal force

NO = -7.235 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated resistance to pressure

Nc,Rd = 36,125 kN

Condition 6.9: NEd <= Nc,Rd (7.24 <= 36.13)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

ly = 100.00 cm

Buckling curve for axis

 $\bar{\gamma}_{yy} = \bar{\gamma}$ = 0.712

yy: A Elastic critical force

 $\bar{\gamma}$ = 0.210

Reduction coefficient

Ncr,y = 71.298 kN

Calculated resistance to buckling

 $\bar{\gamma}_{yy}$ = 0.842

Condition 6.46: NEd <= Nb,Rd,y

Nb,Rd,y = 30.422 kN

Nb,Rd,y (7.24 <= 30.42)

Buckling length zz

lz = 100.00 cm

Relative slenderness zz

 $\bar{\gamma}_{zz}$ = 0.712

Buckling curve for axis zz: A

 $\bar{\gamma}$ = 0.210

Reduction coefficient


 $\bar{\gamma}_{zz}$ = 0.842

Calculated buckling resistance

Nb,Rd,z = 30.422 kN

Condition 6.46: NEd <= Nb,Rd,z (7.24 <= 30.42)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.29$ A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, beginning of the rod)

Calculation normal force NO = -5.774 kN

System rod length

L = 80,000 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 24,000 kN

Condition 6.9: NEd ≤ Nc,Rd (5.77 ≤ 24.00)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

l_y = 80,000 cm

Buckling curve for axis yy

 \bar{y}_y = 0.717

yy: A Elastic critical force

y = 0.210

Reduction coefficient

Ncr,y = 46.634 kN

Calculated resistance to buckling Condition 6.46: NEd ≤

 \bar{y}_y = 0.839

Nb,Rd,y (5.77 ≤ 20.15)

Nb,Rd,y = 20.146 kN

Buckling length zz

Relative slenderness zz

l_z = 80,000 cm

Buckling curve for axis zz: A

 \bar{y}_z = 0.717

Reduction coefficient

y = 0.210

Calculated buckling resistance

 \bar{y}_z = 0.839


Condition 6.46: NEd ≤ Nb,Rd,z (5.77 ≤ 20.15)

Nb,Rd,z = 20.146 kN

STICK 345-312

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 315-278

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 8]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 285-252

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	=	1,920 cm ²
A_y	=	0,958 cm ²
A_z	=	0,958 cm ²
I_x	=	2,881 cm ⁴
I_y	=	1,440 cm ⁴
I_{From-}	=	1,440 cm ⁴
W_y	=	1,071 cm ³
W_z	=	1,071 cm ³
$W_{y,pl}$	=	1,494 cm ³
$W_{z,pl}$	=	1,494 cm ³
$\bar{y}M_0$	=	1,000
$\bar{y}M_1$	=	1,000
$\bar{y}M_2$	=	1,000
A_{net}/A	=	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 255-218

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 225-192

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 7]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 195-158

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

ROD 105-72

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
$\bar{y}M0$ =	1,000
$\bar{y}M1$ =	1,000
$\bar{y}M2$ =	1,000
Anet/A =	0,900


UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$

No influence

STICK 75-38

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)



A_x	1,920 cm ²
A_y	0,958 cm ²
A_z	0,958 cm ²
I_x	2,881 cm ⁴
I_y	1,440 cm ⁴
$I_{y,From-}$	1,440 cm ⁴
W_y	1,071 cm ³
W_z	1,071 cm ³
$W_{y,pl}$	1,494 cm ³
$W_{z,pl}$	1,494 cm ³
$\bar{y}M_0$	1,000

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


No influence

STICK 45-12

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
EUROCODE 3 (EN 1993-1-1:2005)

[m m]

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	1,920 cm ²
A_y	0,958 cm ²
A_z	0,958 cm ²
I_x	2,881 cm ⁴
I_y	1,440 cm ⁴
$I_{y,From-}$	1,440 cm ⁴
W_y	1,071 cm ³
W_z	1,071 cm ³
$W_{y,pl}$	1,494 cm ³
$W_{z,pl}$	1,494 cm ³
$\bar{y}M_0$	1,000
$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{y}=0.00$

No influence

STICK 345-363

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	2,890 cm ²
A_y	1,446 cm ²
A_z	1,446 cm ²
I_x	6,879 cm ⁴
I_y	3,440 cm ⁴
$I_{y,From-}$	3,440 cm ⁴
W_y	2,042 cm ³
W_z	2,042 cm ³
$W_{y,pl}$	2,836 cm ³
$W_{z,pl}$	2,836 cm ³
$\bar{y}M_0$	1,000
$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Calculation normal force

NO = -0.012 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated resistance to pressure

Nc,Rd = 36,125 kN

Condition 6.9: $N_{Ed} \leq N_{c,Rd}$ (0.01 \leq 36.13)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Iy = 100.00 cm

Relative slenderness yy

 \bar{y}_y = 0.712

Buckling curve for axis

 \bar{y} = 0.210

yy: A Elastic critical force

Ncr,y = 71.298 kN

Reduction coefficient

 $\bar{\chi}_y$ = 0.842

Calculated buckling

Nb,Rd,y = 30.422 kN

resistance Condition 6.46: $N_{Ed} \leq$ Nb,Rd,y (0.01 \leq 30.42)

Buckling length zz

Iz = 100.00 cm

Relative slenderness zz

 \bar{y}_z = 0.712

Buckling curve for axis zz: A

 \bar{y}_z = 0.210

Reduction coefficient

= 0.842

Calculated buckling resistance

Nb,Rd,z = 30.422 kN

Condition 6.46: $N_{Ed} \leq N_{b,Rd,z}$ (0.01 \leq 30.42)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

ROD 315-345

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



A_x	2,890 cm ²
A_y	1,446 cm ²
A_z	1,446 cm ²
I_x	6,879 cm ⁴
I_y	3,440 cm ⁴
$I_{y,From-}$	3,440 cm ⁴
W_y	2,042 cm ³
W_z	2,042 cm ³
$W_{y,pl}$	2,836 cm ³
$W_{z,pl}$	2,836 cm ³
$\bar{y}M_0$	1,000
$\bar{y}M_1$	1,000
$\bar{y}M_2$	1,000
A_{net}/A	0,900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.80$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force

NO = 28.838 kN

System rod length

L = 100.00 cm

6.2 BEARING CAPACITY OF CROSS

SECTIONS 6.2.3

Tension Plastic resistance of gross

Npl,Rd = 36,125 kN

section Limit calculation

Nu,Rd = 43,307 kN

resistance of net section


Nt,Rd = 36,125 kN

Calculation resp. for tensioning Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ (28.84 \leq 36.13)

STICK 285-315

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\eta=0.80$

ROD EXPOSED TO CENTRIC TENSION
(load case 3, beginning of the rod)

Calculation normal force	NO =	28.826 kN
System rod length	L =	100.00 cm


6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile		
Plastic resistance of the gross cross-section	Npl,Rd =	36,125 kN
Limit resistance of the net cross-section	Nu,Rd =	43,307 kN
Comput. for tensioning	Nt,Rd =	36,125 kN
Condition 6.5: NEd <= Nt,Rd (28.83 <= 36.13)		

STICK 312-338

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

Calculation normal force	NO =	-7.232 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculated pressure resistance	Nc,Rd =	36,125 kN
Condition 6.9: NEd <= Nc,Rd (7.23 <= 36.13)		

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy		
Relative slenderness yy	Iy =	100.00 cm
Buckling curve for axis yy	$\bar{y}_y = \bar{y}$	0.712
yy: A Elastic critical force	$\bar{y} =$	0.210
Reduction coefficient	Ncr,y =	71,298 kN
Calculated buckling resistance	$\bar{y}_y =$	0.842
Condition 6.46: NEd <= Nb,Rd,y (7.23 <= 30.42)	Nb,Rd,y =	30,422 kN
Buckling length zz	Iz =	100.00 cm
Relative slenderness zz	$\bar{y}_z = \bar{y}$	0.712
Buckling curve for axis zz: A	$\bar{y} =$	0.210
Reduction coefficient	$\bar{y}_z =$	0.842
Calculated buckling resistance	Nb,Rd,z =	30,422 kN
Condition 6.46: NEd <= Nb,Rd,z (7.23 <= 30.42)		

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\eta=0.24$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 278-312

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

Calculation normal force	NO =	-7.251 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculated resistance to pressure	Nc,Rd =	36,125 kN
Condition 6.9: NEd <= Nc,Rd (7.25 <= 36.13)		

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy		
Relative slenderness yy	Iy =	100.00 cm
Buckling curve for axis yy	$\bar{y}_y =$	0.712
yy: A Elastic critical force	$\bar{y} =$	0.210
Reduction coefficient	Ncr,y =	71,298 kN
Calculated resistance to buckling	$\bar{y}_y =$	0.842
Condition 6.46: NEd <= Nb,Rd,y (7.25 <= 30.42)	Nb,Rd,y =	30,422 kN
Buckling length zz	Iz =	100.00 cm
Relative slenderness zz	$\bar{y}_z = \bar{y}$	0.712
Buckling curve for axis zz: A	$\bar{y} =$	0.210
Reduction coefficient	$\bar{y}_z =$	0.842
Calculated buckling resistance	Nb,Rd,z =	30,422 kN
Condition 6.46: NEd <= Nb,Rd,z (7.25 <= 30.42)		

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\eta=0.24$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 252-278

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 4]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	2,890 cm ²
Ay =	1,446 cm ²
Az =	1,446 cm ²
Ix =	6,879 cm ⁴
Iy =	3,440 cm ⁴
I _{From} =	3,440 cm ⁴
Wy =	2,042 cm ³
Wz =	2,042 cm ³
Wy.pl =	2,836 cm ³
Wz.pl =	2,836 cm ³
yM0 =	1,000
yM1 =	1,000
yM2 =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

[m m]

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\eta=0.71$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force	NO =	-21.703 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculation resistance to pressure	Nc,Rd =	36,125 kN
Condition 6.9: NEd <= Nc,Rd (21.70 <= 36.13)		

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy		
Relative slenderness yy	Iy =	100.00 cm
Buckling curve for axis yy: A	$\bar{y}_y =$	0.712
Elastic critical force	$\bar{y} =$	0.210
Reduction coefficient	Ncr,y =	71,298 kN
Calculated resistance to buckling	$\bar{y}_y =$	0.842
Condition 6.46: NEd <= Nb,Rd,y (21.70 <= 30.42)	Nb,Rd,y =	30,422 kN

Buckling length z_z
 Relative slenderness of the z_z
 Buckling curve for axis z_z : A
 Reduction coefficient

$l_z = 100.00$ cm
 $\bar{\lambda}_{z_z} = 0.712$
 $\bar{\lambda}_y = 0.210$
 $\bar{\lambda}_{y,z} = 0.842$


Calculation resistance to buckling
 Condition 6.46: $N_{Ed} \leq N_{b,Rd,z}$ (21.70 \leq 30.42)

$N_{b,Rd,z} = 30,422$ kN

ROD 255-285

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 7,070$ cm²
 $A_y = 3,536$ cm²
 $A_z = 3,536$ cm²
 $I_x = 56,317$ cm⁴
 $I_y = 28,170$ cm⁴
 $I_{From} = 28,170$ cm⁴
 $W_y = 9,343$ cm³
 $W_z = 9,343$ cm³
 $W_{y,pl} = 12,700$ cm³
 $W_{z,pl} = 12,700$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

[m m]

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\lambda} = 0.65$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force NO = 57.668 kN
System rod length L = 100.00 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS


6.2.3 Tensile

Plastic resistance of the gross cross-section $N_{pl,Rd} = 88.375$ kN
Limit resistance of the net cross-section $N_{u,Rd} = 105.94$ kN
Comput. for tensioning $N_{t,Rd} = 88.375$ kN
 Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ (57.67 \leq 88.38)

ROD 225-255

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 7,070$ cm²
 $A_y = 3,536$ cm²
 $A_z = 3,536$ cm²
 $I_x = 56,317$ cm⁴
 $I_y = 28,170$ cm⁴
 $I_{From} = 28,170$ cm⁴
 $W_y = 9,343$ cm³
 $W_z = 9,343$ cm³
 $W_{y,pl} = 12,700$ cm³
 $W_{z,pl} = 12,700$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

[m m]

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\lambda} = 0.65$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force NO = 57.645 kN
System rod length L = 100.00 cm

6.2 BEARING CAPACITY OF CROSS SECTIONS 6.2.3


Tension Plastic resistance of gross section Limit calculation

$N_{pl,Rd} = 88.375$ kN
 $N_{u,Rd} = 105.94$ kN
 $N_{t,Rd} = 88.375$ kN
 Calculation resp. for tensioning Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ (57.65 \leq 88.38)

STICK 195-225

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 7,070$ cm²
 $A_y = 3,536$ cm²
 $A_z = 3,536$ cm²
 $I_x = 56,317$ cm⁴
 $I_y = 28,170$ cm⁴
 $I_{From} = 28,170$ cm⁴
 $W_y = 9,343$ cm³
 $W_z = 9,343$ cm³
 $W_{y,pl} = 12,700$ cm³
 $W_{z,pl} = 12,700$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

[m m]

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\lambda} = 0.98$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force NO = 86.476 kN
System rod length L = 100.00 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS


6.2.3 Tensile

Plastic resistance of the gross cross-section $N_{pl,Rd} = 88.375$ kN
Limit resistance of the net cross-section $N_{u,Rd} = 105.94$ kN
Comput. for tensioning $N_{t,Rd} = 88.375$ kN
 Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ (86.48 \leq 88.38)

ROD 218-252

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 7,070$ cm²
 $A_y = 3,536$ cm²
 $A_z = 3,536$ cm²
 $I_x = 56,317$ cm⁴
 $I_y = 28,170$ cm⁴
 $I_{From} = 28,170$ cm⁴
 $W_y = 9,343$ cm³
 $W_z = 9,343$ cm³
 $W_{y,pl} = 12,700$ cm³
 $W_{z,pl} = 12,700$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

[m m]

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\lambda} = 0.26$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force NO = -21.733 kN
System rod length L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated resistance to pressure $N_{c,Rd} = 88.375$ kN
 Condition 6.9: $N_{Ed} \leq N_{c,Rd}$ (21.73 \leq 88.38)

6.3 ELEMENTS BUCKLING CAPACITY 6.3.1.1 Buckling

capacity **Buckling length** y_y

Relative slenderness y_y

Buckling curve for axis

$\bar{\lambda}_{y,y}$: A **Elastic critical force**

Reduction coefficient

Calculated buckling resistance

$l_y = 100.00$ cm
 $\bar{\lambda}_{y,y} = 0.389$
 $\bar{\lambda}_y = 0.210$
 $N_{cr,y} = 583.86$ kN
 $\bar{\lambda}_{y,y} = 0.956$
 $N_{b,Rd,y} = 84.455$ kN

Condition 6.46: $N_{Ed} \leq N_{b,Rd,y}$ (21.73 \leq 84.45)

Buckling length z_z
Relative slenderness of the z_z
Buckling curve for axis z_z : A

$l_{z_z} = 100.00$ cm
 $\bar{\lambda}_{z_z} = 0.389$
 $\bar{\gamma} = 0.210$


Reduction coefficient
Calculated buckling resistance
Condition 6.46: $N_{Ed} \leq N_{b,Rd,z}$ (21.73 \leq 84.45)

$\bar{\gamma}_{z_z} = 0.956$
 $N_{b,Rd,z} = 84.455$ kN

STICK 192-218

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 7,070$ cm²
 $A_y = 3,536$ cm²
 $A_z = 3,536$ cm²
 $I_x = 56,317$ cm⁴
 $I_y = 28,170$ cm⁴
 $I_{From} = 28,170$ cm⁴
 $W_y = 9,343$ cm³
 $W_z = 9,343$ cm³
 $W_{y,pl} = 12,700$ cm³
 $W_{z,pl} = 12,700$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.43$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force

NO = -36.197 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculated pressure resistance

$N_{c,Rd} = 88,375$ kN

Condition 6.9: $N_{Ed} \leq N_{c,Rd}$ (36.20 \leq 88.38)

6.3 BURNING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity **Buckling length**

yy Relative slenderness

$l_{y_y} = 100.00$ cm

yy Buckling curve for axis

$\bar{\lambda}_{y_y} = 0.389$

yy: A Elastic critical force

$\bar{\gamma} = 0.210$

Reduction coefficient

$N_{cr,y} = 583.86$ kN

Calculated buckling

$\bar{\gamma}_{y_y} = 0.956$

resistance Condition 6.46: $N_{Ed} \leq$

$N_{b,Rd,y} = 84.455$ kN

$N_{b,Rd,y}$ (36.20 \leq 84.45)

Buckling length z_z

$l_{z_z} = 100.00$ cm

Relative slenderness z_z

$\bar{\lambda}_{z_z} = 0.389$

Buckling curve for axis z_z : A

$\bar{\gamma} = 0.210$

Reduction coefficient

$\bar{\gamma}_{z_z} = 0.956$

Calculated resistance to buckling

$N_{b,Rd,z} = 84.455$ kN

Condition 6.46: $N_{Ed} \leq N_{b,Rd,z}$ (36.20 \leq 84.45)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.43$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 158-192

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 3]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 7,070$ cm²
 $A_y = 3,536$ cm²
 $A_z = 3,536$ cm²
 $I_x = 56,317$ cm⁴
 $I_y = 28,170$ cm⁴
 $I_{From} = 28,170$ cm⁴
 $W_y = 9,343$ cm³
 $W_z = 9,343$ cm³
 $W_{y,pl} = 12,700$ cm³
 $W_{z,pl} = 12,700$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.43$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

Calculation normal force

NO = -36.226 kN

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

$N_{c,Rd} = 88,375$ kN

Condition 6.9: $N_{Ed} \leq N_{c,Rd}$ (36.23 \leq 88.38)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length** yy

Relative slenderness yy

$l_{y_y} = 100.00$ cm

Buckling curve for axis

$\bar{\lambda}_{y_y} = \bar{\gamma} = 0.389$

yy: A Elastic critical force

$\bar{\gamma} = 0.210$

Reduction coefficient

$N_{cr,y} = 583.86$ kN

Calculated resistance to

$\bar{\gamma}_{y_y} = 0.956$

buckling Condition 6.46: $N_{Ed} \leq$

$N_{b,Rd,y} = 84.455$ kN

$N_{b,Rd,y}$ (36.23 \leq 84.45)

Buckling length z_z

$l_{z_z} = 100.00$ cm

Relative slenderness z_z

$\bar{\lambda}_{z_z} = 0.389$

Buckling curve for axis z_z : A

$\bar{\gamma} = 0.210$

Reduction coefficient

$\bar{\gamma}_{z_z} = 0.956$

Calculated buckling resistance

$N_{b,Rd,z} = 84.455$ kN

Condition 6.46: $N_{Ed} \leq N_{b,Rd,z}$ (36.23 \leq 84.45)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.43$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 165-195

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



$A_x = 11,170$ cm²
 $A_y = 5,581$ cm²
 $A_z = 5,581$ cm²
 $I_x = 141,77$ cm⁴
 $I_y = 70,920$ cm⁴
 $I_{From} = 70,920$ cm⁴
 $W_y = 18,639$ cm³
 $W_z = 18,639$ cm³
 $W_{y,pl} = 25,318$ cm³
 $W_{z,pl} = 25,318$ cm³
 $\bar{y}_{M0} = 1,000$
 $\bar{y}_{M1} = 1,000$
 $\bar{y}_{M2} = 1,000$
 $A_{net}/A = 0,900$

($f_y = 12.5$ kN/cm², $f_u = 18.5$ kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma} = 0.62$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force

NO = 86.453 kN

System rod length

L = 100.00 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile

Plastic resistance of the gross cross-

$N_{pl,Rd} = 139.63$ kN

section Limit resistance of the

$N_{u,Rd} = 167.38$ kN

net cross-

section Comput. for tensioning


$N_{t,Rd} = 139.63$ kN

Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ (86.45 \leq 139.63)

STICK 135-165

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy,pl =	25.318 cm ³
Wz,pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.82$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force	NO =	115.27 kN
System rod length	L =	100.00 cm


6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile		
Plastic resistance of the gross cross-section Limit resistance of the	Npl,Rd =	139.63 kN
	Nu,Rd =	167.38 kN
net cross-section Comput. for tension Condition 6.5: $NEd \leq Nt,Rd$ (115.27 \leq 139.63)	Nt,Rd =	139.63 kN

ROD 105-135

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy,pl =	25.318 cm ³
Wz,pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.82$

ROD EXPOSED TO CENTRIC TENSION

(load case 3, beginning of the rod)

Calculation normal force	NO =	115.24 kN
System rod length	L =	100.00 cm


6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile		
Plastic resistance of the gross cross-section Limit resistance of the	Npl,Rd =	139.63 kN
	Nu,Rd =	167.38 kN
net cross-section Comput. for tension Condition 6.5: $NEd \leq Nt,Rd$ (115.24 \leq 139.63)	Nt,Rd =	139.63 kN

STICK 132-158

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy,pl =	25.318 cm ³
Wz,pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Calculation normal force	NO =	-50.701 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculation resistance to pressure Condition 6.9: $NEd \leq Nc,Rd$ (50.70 \leq 139.63)	Nc,Rd =	139.63 kN

6.3 BURNING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity Buckling length yy Relative slenderness	I _y =	100.00 cm
	y _y =	0.308
	y =	0.210
yy: A Elastic critical force Reduction coefficient	Ncr,y =	1469.9 kN
Calculated buckling resistance Condition 6.46: $NEd \leq Nb,Rd,y$ (50.70 \leq 136.21)	y _y =	0.976
	Nb,Rd,y =	136.21 kN

Buckling length zz Relative slenderness zz	I _z =	100.00 cm
	y _z =	0.308
Buckling curve for axis zz: A Reduction coefficient	y =	0.210
	y _z =	0.976
Calculated buckling resistance Condition 6.46: $NEd \leq Nb,Rd,z$ (50.70 \leq 136.21)	Nb,Rd,z =	136.21 kN

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{\gamma}=0.37$


A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 98-132

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	11.170 cm ²
Ay =	5.581 cm ²
Az =	5.581 cm ²
Ix =	141.77 cm ⁴
Iy =	70.920 cm ⁴
I _{From} =	70.920 cm ⁴
Wy =	18.639 cm ³
Wz =	18.639 cm ³
Wy,pl =	25.318 cm ³
Wz,pl =	25.318 cm ³
yM0 =	1.000
yM1 =	1.000
yM2 =	1.000
Anet/A =	0.900

[m m]

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

Calculation normal force	NO =	-50.742 kN
System rod length	L =	100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure		
Calculation resistance to pressure Condition 6.9: $NEd \leq Nc,Rd$ (50.74 \leq 139.63)	Nc,Rd =	139.63 kN

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1

Buckling capacity Buckling length yy Relative slenderness yy	I _y =	100.00 cm
	y _y =	0.308
	y =	0.210
yy: A Elastic critical force Reduction coefficient	Ncr,y =	1469.9 kN
Calculated resistance to buckling Condition 6.46: $NEd \leq Nb,Rd,y$ (50.74 \leq 136.21)	y _y =	0.976
	Nb,Rd,y =	136.21 kN

Buckling length zz Relative slenderness zz	I _z =	100.00 cm
	y _z =	0.308
Buckling curve for axis zz: A Reduction coefficient	y =	0.210
	y _z =	0.976
Calculated buckling resistance Condition 6.46: $NEd \leq Nb,Rd,z$ (50.74 \leq 136.21)	Nb,Rd,z =	136.21 kN

UTILIZATION FACTORS BY LOAD COMBINATIONS


3. $\bar{\gamma}=0.37$

A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, end of rod)

STICK 72-98
CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 2]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax = 11.170 cm²
 Ay = 5.581 cm²
 Az = 5.581 cm²
 Ix = 141.77 cm⁴
 Iy = 70.920 cm⁴
 I_{From} = 70.920 cm⁴
 Wy = 18.639 cm³
 Wz = 18.639 cm³
 Wy,pl = 25.318 cm³
 Wz,pl = 25.318 cm³
 yM0 = 1.000
 yM1 = 1.000
 yM2 = 1.000
 Anet/A = 0.900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
 3. $\bar{\gamma}=0.48$

A ROD EXPOSED TO CENTRAL PRESSURE
 (load case 3, end of rod)

Calculation normal force NO = -65.217 kN
System rod length L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS
 Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure
Calculation resistance to pressure Nc,Rd = 139.63 kN
Condition 6.9: NEd <= Nc,Rd (65.22 <= 139.63)


6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity **Buckling length yy** ly = 100.00 cm
 Relative slenderness yy $\bar{\gamma}_y = 0.308$
 Buckling curve for axis yy = $\bar{\gamma}_y = 0.210$
 yy: A **Elastic critical force** Ncr,y = 1469.9 kN
 Reduction coefficient $\bar{\gamma}_y = 0.976$
Calculated buckling resistance Condition 6.46: NEd <= Nb,Rd,y (65.22 <= 136.21) Nb,Rd,y = 136.21 kN

Buckling length zz lz = 100.00 cm
 Relative slenderness zz $\bar{\gamma}_z = \bar{\gamma}_y = 0.308$
 Buckling curve for axis zz: A $\bar{\gamma}_z = \bar{\gamma}_y = 0.210$
 Reduction coefficient = 0.976
Calculated buckling resistance Nb,Rd,z = 136.21 kN
Condition 6.46: NEd <= Nb,Rd,z (65.22 <= 136.21)

STICK 75-105
CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax = 16.630 cm²
 Ay = 7.809 cm²
 Az = 7.809 cm²
 Ix = 269.75 cm⁴
 Iy = 134.94 cm⁴
 I_{From} = 134.94 cm⁴
 Wy = 30.358 cm³
 Wz = 30.358 cm³
 Wy,pl = 41.306 cm³
 Wz,pl = 41.306 cm³
 yM0 = 1.000
 yM1 = 1.000
 yM2 = 1.000
 Anet/A = 0.900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
 3. $\bar{\gamma}=0.69$

ROD EXPOSED TO CENTRIC TENSION
 (load case 3, beginning of the rod)


Calculation normal force NO = 144.06 kN
System rod length L = 100,000 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile
Plastic resistance of the gross cross-section Npl,Rd = 207.88 kN
Limit resistance of the net cross-section Nu,Rd = 249.20 kN
Comput. for tensioning Nt,Rd = 207.88 kN
Condition 6.5: NEd <= Nt,Rd (144.06 <= 207.88)

ROD 45-75
CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax = 16.630 cm²
 Ay = 7.809 cm²
 Az = 7.809 cm²
 Ix = 269.75 cm⁴
 Iy = 134.94 cm⁴
 I_{From} = 134.94 cm⁴
 Wy = 30.358 cm³
 Wz = 30.358 cm³
 Wy,pl = 41.306 cm³
 Wz,pl = 41.306 cm³
 yM0 = 1.000
 yM1 = 1.000
 yM2 = 1.000
 Anet/A = 0.900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
 3. $\bar{\gamma}=0.69$

ROD EXPOSED TO CENTRIC TENSION
 (load case 3, beginning of the rod)


Calculation normal force NO = 144.01 kN
System rod length L = 100.00 cm

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile
Plastic resistance of the gross cross-section Npl,Rd = 207.88 kN
Limit resistance of the net cross-section Nu,Rd = 249.20 kN
Comput. for tensioning Nt,Rd = 207.88 kN
Condition 6.5: NEd <= Nt,Rd (144.01 <= 207.88)

ROD 15-45
CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax = 16.630 cm²
 Ay = 7.809 cm²
 Az = 7.809 cm²
 Ix = 269.75 cm⁴
 Iy = 134.94 cm⁴
 I_{From} = 134.94 cm⁴
 Wy = 30.358 cm³
 Wz = 30.358 cm³
 Wy,pl = 41.306 cm³
 Wz,pl = 41.306 cm³
 yM0 = 1.000
 yM1 = 1.000
 yM2 = 1.000
 Anet/A = 0.900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
 3. $\bar{\gamma}=0.83$

ROD EXPOSED TO CENTRIC TENSION
 (load case 3, beginning of the rod)

 Calculation normal force
 System rod length

 $N_{Ed} = 172.81 \text{ kN}$
 $L = 100,000 \text{ cm}$

 Plastic calc. resistance of gross
 cross-section Limit calc.

 $N_{pl,Rd} = 207.88 \text{ kN}$
 $N_{u,Rd} = 249.20 \text{ kN}$

resistance of net cross -section

 $N_{t,Rd} = 207.88 \text{ kN}$

 Calcul. for tension Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ ($172.81 \leq 207.88$)

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tightening

UTILIZATION FACTORS BY LOAD COMBINATIONS

 3. $\bar{\gamma} = 0.39$
ROD EXPOSED TO CENTRIC TENSION

(load case 3, end of rod)

Calculation normal force

 $N_{O} = 9.245 \text{ kN}$

System rod length

 $L = 128.06 \text{ cm}$
6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.3 Tensile

 Plastic resistance of the gross cross-
 section Limit resistance of the

 $N_{pl,Rd} = 24,000 \text{ kN}$
 $N_{u,Rd} = 28,771 \text{ kN}$


 net cross-
 section Comput. for tensioning

 $N_{t,Rd} = 24,000 \text{ kN}$

 Condition 6.5: $N_{Ed} \leq N_{t,Rd}$ ($9.24 \leq 24.00$)

STICK 63-45


 CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

 $A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{z,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M0 = 1,000$
 $\bar{y}M1 = 1,000$
 $\bar{y}M2 = 1,000$
 $A_{net}/A = 0,900$
 $(f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2)$

[m m]

STICK 45-6

 CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 5]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS

 $A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{z,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M0 = 1,000$
 $\bar{y}M1 = 1,000$
 $\bar{y}M2 = 1,000$
 $A_{net}/A = 0,900$
 $(f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2)$

[m m]

Calculation normal force

 $N_{O} = -9.245 \text{ kN}$

System rod length

 $L = 128.06 \text{ cm}$
5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

 $N_{c,Rd} = 24,000 \text{ kN}$

 Condition 6.9: $N_{Ed} \leq N_{c,Rd}$ ($9.24 \leq 24.00$)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

 $l_{yy} = 128.06 \text{ cm}$

Buckling curve for axis

 $\bar{y}_{yy} = 1.148$

yy: A Elastic critical force

 $\bar{y} = 0.210$

Reduction coefficient

 $N_{cr,yy} = 18.199 \text{ kN}$

Calculated resistance to

 $\bar{y}_{yy} = 0.563$

 buckling Condition 6.46: $N_{Ed} \leq$
 $N_{b,Rd,yy} = 13.522 \text{ kN}$
 $N_{b,Rd,yy}$ ($9.24 \leq 13.52$)

Buckling length zz

 $l_{zz} = 128.06 \text{ cm}$

Relative slenderness zz

 $\bar{y}_{zz} = 1.148$

Buckling curve for axis zz: A

 $\bar{y} = 0.210$

Reduction coefficient

 $\bar{y}_{zz} = 0.563$

Calculated buckling resistance

 $N_{b,Rd,zz} = 13.522 \text{ kN}$

 Condition 6.46: $N_{Ed} \leq N_{b,Rd,zz}$ ($9.24 \leq 13.52$)

UTILIZATION FACTORS BY LOAD COMBINATIONS

 3. $\bar{\gamma} = 0.68$
A ROD EXPOSED TO CENTRAL PRESSURE

(load case 3, beginning of the rod)


UTILIZATION FACTORS BY LOAD COMBINATIONS

 3. $\bar{\gamma} = 0.00$

No influence

STICK 165-132

 CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
 EUROCODE 3 (EN 1993-1-1:2005)


GEOMETRIC CHARACTERISTICS OF SECTIONS

 $A_x = 1,920 \text{ cm}^2$
 $A_y = 0,958 \text{ cm}^2$
 $A_z = 0,958 \text{ cm}^2$
 $I_x = 2,881 \text{ cm}^4$
 $I_y = 1,440 \text{ cm}^4$
 $I_{z,From} = 1,440 \text{ cm}^4$
 $W_y = 1,071 \text{ cm}^3$
 $W_z = 1,071 \text{ cm}^3$
 $W_{y,pl} = 1,494 \text{ cm}^3$
 $W_{z,pl} = 1,494 \text{ cm}^3$
 $\bar{y}M0 = 1,000$
 $\bar{y}M1 = 1,000$
 $\bar{y}M2 = 1,000$
 $A_{net}/A = 0,900$
 $(f_y = 12.5 \text{ kN/cm}^2, f_u = 18.5 \text{ kN/cm}^2)$

[m m]

STICK 63-93

 CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 1]
 EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	16.630 cm ²
Ay =	7.809 cm ²
Az =	7.809 cm ²
Ix =	269.75 cm ⁴
Iy =	134.94 cm ⁴
I _{From} =	134.94 cm ⁴
Wy =	30.358 cm ³
Wz =	30.358 cm ³
Wy,pl =	41.306 cm ³
Wz,pl =	41.306 cm ³
y _{M0} =	1.000
y _{M1} =	1.000
y _{M2} =	1.000
Anet/A =	0.900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

UTILIZATION FACTORS BY LOAD COMBINATIONS
3. $\bar{y}=0.32$


A ROD EXPOSED TO CENTRAL PRESSURE
(load case 3, end of rod)

Calculation normal force	NO =	-65,269 kN
--------------------------	------	------------

STICK 135-98

CROSS SECTION : Tubular [EN-AW-6082-T6] [Set: 6]
EUROCODE 3 (EN 1993-1-1:2005)

GEOMETRIC CHARACTERISTICS OF SECTIONS



Ax =	1,920 cm ²
Ay =	0,958 cm ²
Az =	0,958 cm ²
Ix =	2,881 cm ⁴
Iy =	1,440 cm ⁴
I _{From} =	1,440 cm ⁴
Wy =	1,071 cm ³
Wz =	1,071 cm ³
Wy,pl =	1,494 cm ³
Wz,pl =	1,494 cm ³
y _{M0} =	1,000
y _{M1} =	1,000
y _{M2} =	1,000
Anet/A =	0,900

(fy = 12.5 kN/cm², fu = 18.5 kN/cm²)

System rod length

L = 100.00 cm

5.5 CLASSIFICATION OF CROSS SECTIONS

Section class 1

6.2 LOAD CAPACITY OF CROSS-SECTIONS

6.2.4 Pressure

Calculation resistance to pressure

Nc,Rd = 207.88 kN

Condition 6.9: NEd <= Nc,Rd (65.27 <= 207.88)

6.3 BENDING CAPACITY OF ELEMENTS 6.3.1.1 Buckling

capacity Buckling length yy

Relative slenderness yy

l_y = 100.00 cm

Buckling curve for axis yy

\bar{y}_{yy} = 0.273

yy: A Elastic critical force

\bar{y} = 0.210

Reduction coefficient

Ncr,y = 2796.8 kN

Calculated buckling resistance

\bar{y}_{yy} = 0.984

Condition 6.46: NEd <= Nb,Rd,y (65.27 <= 204.51)

Nb,Rd,y = 204.51 kN

Buckling length zz

Relative slenderness zz

l_z = 100.00 cm

Buckling curve for axis zz: A

\bar{y}_{zz} = 0.273

Reduction coefficient

\bar{y} = 0.210

Calculated buckling resistance

\bar{y}_{zz} = 0.984

Condition 6.46: NEd <= Nb,Rd,z (65.27 <= 204.51)





Nb,Rd,z = 204.51 kN

UTILIZATION FACTORS BY LOAD COMBINATIONS

3. $\bar{y}=0.00$

No influence

TEHNICAL DRAWINGS




ST 12000

ST 9000

ST 6000

ST 3000



Rods and sheets - specification

POS	Type	Material	n (pieces)	Width (mm)	Thickness (mm)	Length (mm)	Unit weight (kg/m)	Weight per piece (kg)	Total weight (kg)
STT 3000 (1 pc)									
1	Ø6.9x6 EN AW-6062-T6 3					3000.00	4.22	12.66	37.97
2	Ø6.9x2.5 EN AW-6062-T6 3					1171.84	0.52	0.61	1.82
3	Ø6.9x2.5 EN AW-6062-T6 3					1171.84	0.52	0.61	1.82
4	Ø6.9x2.5 EN AW-6062-T6 3					1172.13	0.52	0.61	1.82
5	Ø6.9x2.5 EN AW-6062-T6 6					711.10	0.92	0.37	2.21
6	Ø6.9x2.5 EN AW-6062-T6 6					711.10	0.92	0.37	2.21
Total									47.84

STT 6000 (1 pc)									
1	Ø76 1x5 EN AW-6062-T6 3					3000.00	3.02	9.06	27.14
2	Ø6.9x2.5 EN AW-6062-T6 3					1192.43	0.52	0.62	1.85
3	Ø6.9x2.5 EN AW-6062-T6 3					1192.43	0.52	0.62	1.85
4	Ø6.9x2.5 EN AW-6062-T6 3					1192.43	0.52	0.62	1.85
5	Ø6.9x2.5 EN AW-6062-T6 3					723.90	0.52	0.37	1.12
6	Ø6.9x2.5 EN AW-6062-T6 3					723.90	0.52	0.37	1.12
7	Ø6.9x2.5 EN AW-6062-T6 3					723.90	0.52	0.37	1.12
8	Ø6.9x2.5 EN AW-6062-T6 3					723.90	0.52	0.37	1.12
Total									37.19

STT 9000 (1 pc)									
1	Ø60.3x4 EN AW-6062-T6 2					3000.00	1.91	5.73	11.46
2	Ø60.3x4 EN AW-6062-T6 1					3000.00	1.91	5.73	5.73
3	Ø6.9x2.5 EN AW-6062-T6 3					1217.72	0.52	0.63	1.89
4	Ø6.9x2.5 EN AW-6062-T6 3					1217.72	0.52	0.63	1.89
5	Ø6.9x2.5 EN AW-6062-T6 3					1217.72	0.52	0.63	1.89
6	Ø6.9x2.5 EN AW-6062-T6 3					739.70	0.52	0.38	1.15
7	Ø6.9x2.5 EN AW-6062-T6 3					739.70	0.52	0.38	1.15
8	Ø6.9x2.5 EN AW-6062-T6 6					739.70	0.52	0.38	2.30
Total									27.46

STT 12000 (1 pc)									
1	Ø33.7x3 EN AW-6062-T6 3					3000.00	0.78	2.34	7.03
2	Ø6.9x2.5 EN AW-6062-T6 5					766.30	0.52	0.40	5.95
3	Ø6.9x2.5 EN AW-6062-T6 3					1228.06	0.52	0.64	1.91
4	Ø6.9x2.5 EN AW-6062-T6 3					1228.06	0.52	0.64	1.92
5	Ø6.9x2.5 EN AW-6062-T6 3					1228.06	0.52	0.64	1.91
Total									18.71

Profiles - recap

Profile type	Material	Unit weight (kg/m)	Total weight (kg)
Ø6.9x6	EN AW-6062-T6	4.22	37.97
Ø33.7x3	EN AW-6062-T6	0.78	7.03
Ø76 1x5	EN AW-6062-T6	3.02	27.14
Ø60.3x4	EN AW-6062-T6	1.91	17.19
Ø6.9x2.5	EN AW-6062-T6	0.52	41.87
Total			131.20

Summary recapitulation

Item	Unit weight (kg)	Total weight (kg)
ST 3000 (0 pcs)	0.00	0.00
ST 6000 (0 pcs)	0.00	0.00
ST 9000 (0 pcs)	0.00	0.00
ST 12000 (0 pcs)	0.00	0.00
STT 3000 (1 pc)	47.84	47.84
STT 6000 (1 pc)	37.19	37.19
STT 9000 (1 pc)	27.46	27.46
STT 12000 (1 pc)	18.71	18.71
Total		131.20
Total (+ for bonding agents 3%)		136.14

PROJEKTANT: _____

INVESTOR: _____

Objekat: _____

Lokacija: _____

Glavni inženjer: _____

Vrsta tehničke dokumentacije: _____

Dio tehničke dokumentacije: KONSTRUKCIJA

RAZMJERA: R=1:10

Grafička dokumentacija

Br. priloga: 01

Crtež: _____

PREPARATION AND PRODUCTION OF SAMPLES

During the preparation of the material, the following guidelines were followed:

- When welding aluminum before and after each layer of weld, it is necessary to perform cleaning in order to reduce the presence of Al₂O₃, cleaning must be done mechanically with a brush with stainless steel wires;
- After mechanical cleaning of the surface, it is necessary to perform welding as soon as possible in order to avoid the re-formation of aluminum oxide, within 4 hours at the latest;
- When welding aluminum before and after each layer of weld, it is necessary to perform cleaning in order to reduce the presence of Al₂O₃.
- You should brush until it loses its shine. It should not be shiny as this is usually an indication that there is still an outer layer on the metal.
- The use of points with a wire brush or anything similar is not recommended because aluminum is soft. It will not clean the oxide; it will only embed it further into the metal due to the high speed of the wheel heating the metal.
- If using a wire brush, be sure to rub in one direction only, as back and forth brushing can also push the oxide further into the aluminum.
- Before welding, thoroughly flame dry the area around the joint being welded;
- Flushing the hose for a short time using a torch trigger can help reduce the amount of porosity, which directly reduces the moisture in the hose. If this is done with a MIG welding torch (GAW, gas metal arc welding) do not forget to turn off the wire feed!
- If the first seam is of poor quality due to the above, do a test weld on a spare or sample material and then start welding on the target material.

Welding wire

- For welding AW 6082 T6 alloy, one of the two suggested wires should be used

- ER 4043 (AlSi5)
- ER 5356 (AlMg5)



Protective gas

- Shielding gases in MIG welding - argon

Free wire end

- The free wire end is the length from the exit from the contact guide to the start of the electric arc, and should be 13 times the wire diameter, but not more than 20 mm.

Welding angle



7.17 Suggested parameters for fillet welding – argon shielding.







EXPERIMENTAL INVESTIGATION

The experimental investigation was conducted at the Laboratory of the Faculty of Civil Engineering, University of Montenegro. To replicate the truss supports, the truss was installed horizontally and positioned perpendicular to a closed frame. One end of the truss was bolted to the frame, while at the opposite end, hydraulic presses applied load at the nodes, as illustrated in the figure.

Load measurements were taken using load cells placed beneath the hydraulic presses. Stresses in the chord and brace members were determined indirectly by measuring strains using strain gauges. These strain gauges were installed on compressed diagonal brace members at their mid-span. Each member had three strain gauges in the cross-section, positioned parallel to the member's span.

In addition to the brace members, strain gauges were also applied to the chord members using the same methodology. The chord members selected for strain gauge placement corresponded to those experiencing the highest stress utilization, as determined by the FEM model. The strain gauges used in this experiment were TML FLAB-6-23-5LJC-F.

Global displacement was measured using two displacement transducers to ensure that the load was applied evenly and simultaneously. The load step was set at **0.5 kN/min**, with a maximum load of **10.5 kN**.



EXPERIMENTAL VS FEM MODEL RESULTS

At the following table is given commparassion of the forces inside brace and chord members thru experiment (EXP) and thru the FEM modeling (FEM) and difference.



Member	Load step	1	2	4	5	6	7	8	9	10
B1	EXP	-0.91	-1.73	-3.38	-4.20	-5.01	-5.83	-6.70	-7.56	-8.42
	FEM	-0.92	-1.85	-3.70	-4.62	-5.54	-6.47	-7.39	-8.32	-9.24
	Diference	1.97	6.49	8.49	8.99	9.59	9.79	9.35	9.07	8.85
B2	EXP	-0.80	-1.69	-3.34	-4.17	-4.99	-5.77	-6.57	-7.39	-8.15
	FEM	-0.92	-1.85	-3.70	-4.62	-5.54	-6.47	-7.39	-8.32	-9.24
	Diference	13.71	8.70	9.72	9.77	10.06	10.72	11.15	11.08	11.80
B3	EXP	-0.88	-1.80	-3.52	-4.38	-5.21	-6.06	-6.95	-7.82	-8.67
	FEM	-0.92	-1.85	-3.70	-4.62	-5.54	-6.47	-7.39	-8.32	-9.24
	Diference	4.35	2.71	4.63	5.17	6.06	6.24	5.92	5.91	6.15
TC1	EXP	1.76	3.86	7.78	9.69	11.50	13.32	15.16	17.00	18.74
	FEM	2.16	4.32	8.64	10.80	12.96	15.12	17.28	19.44	21.60
	Diference	18.54	10.71	10.00	10.27	11.23	11.88	12.27	12.54	13.23
TC2	EXP	1.56	3.15	6.17	7.68	9.18	10.67	12.20	13.74	15.22
	FEM	1.44	2.88	5.76	7.21	8.65	10.09	11.53	12.97	14.41
	Diference	8.12	9.36	7.06	6.65	6.12	5.75	5.85	5.92	5.63
CC1	EXP	-3.61	-7.44	-14.59	-18.16	-21.66	-25.13	-28.67	-32.38	-39.49
	FEM	-3.61	-7.23	-14.46	-18.07	-21.68	-25.30	-28.91	-32.53	-36.14
	Diference	0.01	3.00	0.91	0.51	0.13	0.67	0.85	0.45	9.26

*DIFFERENCE= (FEM-EXP)/FEM*100

B1, B2, B3- compressed diagonal brace members

TC1, TC2- tensioned chord members

CC1- compressed chord member



MEASURED FORCES INSIDE MEMBERS COMPARED TO THE FEM FORCES FROM THE MODEL

CERTIFICATES FOR EN AW-6082-T6

Sertifika No (Certificate Number)	249	Tarih (Date)	06.03.2024
---	-----	------------------------	------------

Genel Bilgi (General Information)

Formu (Form)	BORU	Lot No (Lot/Batch No)	140305
Ölçüleri (Dimensions)	25X3	Miktar (Kg) (Quantity)	-
Alaşım (Alloy)	6082	Adet (Pieces)	-
Temper (Temper)	T6	Standartlar (Standards)	EN 573-3 EN 755-2

Kimyasal Analiz (Chemical Analysis)

DEĞERLER (VALUES)	ELEMENTLER (%) (Elements)										
STANDART	Fe	Si	Mn	Cr	Ti	Cu	Mg	Zn	Each	Total	Al
Min.		0,70	0,40				0,60				
Max.	0,50	1,30	1,00	0,25	0,10	0,10	1,20	0,20	0,050	0,15	
TEST SONUÇLARI (%) (Test Results)											
	0,23	0,93	0,50	0,01	0,01	0,02	0,72	0,02			

Mekanik Özellikler (Mechanical Properties)

1 Mpa = 1 N/mm² = 0.145 ksi = 0.102 kgf/mm²

STANDART	Çekme Dayanımı (Mpa) (Tensile Strength)	Akma Dayanımı (Mpa) (Yield Strength)	Uzama (%) (Elongation)	Sertlik (HB) (Hardness)
Min.	310	260	10	95
Max.				
TEST SONUÇLARI (%) (Test Results)				
	325	271	10	95

Ultrasonik Muayene (Ultrasonic Inspection)

Uygulandı (Done)	Uygulandı İse, Standartı (If Done, Standarts)	Uygulanmadı (Not Done)	X
---------------------	--	---------------------------	----------

Onay (Approval)

Seykoç Alüminyum bu uygunluk sertifikası ile, müşteriye teslim edilen ve yukarıda özellikleri tanımlanan ürünlerin; müşteri sipariş şartlarını sağladığını, rapor üzerinde belirtilen teknik değerlerin doğruluğunu ve uluslararası standart şartlarına uygunluğunu beyan ve taahhüt eder.

Seykoç Alüminyum with this conformity certificate, the products delivered to the customer and defined above features; customer order conditions, the accuracy of the technical values stated on the report and compliance with international standard requirements.

Bu Uygunluk Sertifikası, TS EN 10204 standardının 3.1 formatına uygun olarak hazırlanmıştır.

This Conformity Of Certificate was prepared in format 3.1 in accordance with TS EN 10204 standart

Bu Uygunluk Sertifikası, üretici firmanın orijinal sertifika bilgilerini içermektedir.

This Conformity of Certificate contains the information of the manufacturer's original certificate.

Kalite Kontrol Departmanı
(Quality Control Department)

Şahin ARSLAN

QUALITY CONTROL
DEPT.
SEYKOÇ ALÜMİNYUM



Seykoç Alüminyum Pazarlama Ve Sanayi Ticaret Ltd. Şti.

Akse Mahallesi Nazım Hikmet Caddesi 536. Sokak No:7 Çayırova KOCAELİ TÜRKİYE

Tel: +90 262 743 88 88 Pbx Faks: +90 262 743 11 11 Web: seykok.com.tr E-Mail: seykok@seykok.com.tr

Sertifika No (Certificate Number)	3885	Tarih (Date)	27.03.2024
---	------	------------------------	------------

Genel Bilgi (General Information)

Formu (Form)	BORU	Lot No (Lot/Batch No)	10895
Ölçüleri (Dimensions)	32X3,5	Miktar (Kg) (Quantity)	534
Alaşım (Alloy)	6082	Adet (Pieces)	-
Temper (Temper)	T6	Standartlar (Standards)	EN 573-3 EN 755-2

Kimyasal Analiz (Chemical Analysis)

DEĞERLER (VALUES)	ELEMENTLER (%) (Elements)										
STANDART	Fe	Si	Mn	Cr	Ti	Cu	Mg	Zn	Each	Total	Al
Min.		0,70	0,40				0,60				
Max.	0,50	1,30	1,00	0,25	0,10	0,10	1,20	0,20	0,050	0,15	
TEST SONUÇLARI (%) (Test Results)											
	0,22	0,83	0,45	0,01	0,02	0,07	0,66	0,02			

Mekanik Özellikler (Mechanical Properties)

1 Mpa = 1 N/mm² = 0.145 ksi = 0.102 kgf/mm²

STANDART	Çekme Dayanımı (Mpa) (Tensile Strength)	Akma Dayanımı (Mpa) (Yield Strength)	Uzama (%) (Elongation)	Sertlik (HB) (Hardness)
Min.	290	250	8	95
Max.				
TEST SONUÇLARI (%) (Test Results)				
	319	268	11	95

Ultrasonik Muayene (Ultrasonic Inspection)

Uygulandı (Done)	Uygulandı İse, Standartı (If Done, Standarts)	Uygulanmadı (Not Done)	X
---------------------	--	---------------------------	----------

Onay (Approval)

Seykoç Alüminyum bu uygunluk sertifikası ile, müşteriye teslim edilen ve yukarıda özellikleri tanımlanan ürünlerin; müşteri sipariş şartlarını sağladığını, rapor üzerinde belirtilen teknik değerlerin doğruluğunu ve uluslararası standart şartlarına uygunluğunu beyan ve taahhüt eder.

Seykoç Alüminyum with this conformity certificate, the products delivered to the customer and defined above features; customer order conditions, the accuracy of the technical values stated on the report and compliance with international standard requirements.

Bu Uygunluk Sertifikası, TS EN 10204 standardının 3.1 formatına uygun olarak hazırlanmıştır.

This Conformity Of Certificate was prepared in format 3.1 in accordance with TS EN 10204 standart

Bu Uygunluk Sertifikası, üretici firmanın orijinal sertifika bilgilerini içermektedir.

This Conformity of Certificate contains the information of the manufacturer's original certificate.

Kalite Kontrol Departmanı
(Quality Control Department)

Şahin ARSLAN

QUALITY CONTROL
DEPT.
SEYKOÇ ALÜMİNYUM



Seykoç Alüminyum Pazarlama Ve Sanayi Ticaret Ltd. Şti.

Akse Mahallesi Nazım Hikmet Caddesi 536. Sokak No:7 Çayırova KOCAELİ TÜRKİYE

Tel: +90 262 743 88 88 Pbx Faks: +90 262 743 11 11 Web: seykok.com.tr E-Mail: seykok@seykok.com.tr